

SuperSolar Summer Technical Meeting 5 - 6 July 2016

The UK Solar Farm Assemblage: a challenge for the National Grid?

Diane Palmer

Elena Koubli

Purpose of Research

Determine impact
of PV on the Grid:

- How to measure it
- Where
- When




Outline


- Where are the solar farms?
- Grid stresses:
 - Highest number of solar farms
 - Highest solar farm capacity
 - Distance to nearest grid connection point
 - Imbalance of supply and demand
- Calculation of Solar Farm Output
- How output varies in time
- Consumption versus demand
- Achievement of Capacity

Where are the Solar Farms in the UK?

Number and Total Capacity (MW) of Solar Farms
2015






The larger and hotter the circle, the greater the capacity of the solar farm




Department of Climate Change
Renewable Energy Planning
database, REPD 2015 (575 x 1-50MW
installations at September 2015)

Analysis at the DNO Level


No. Solar Farms per DNO 2015



Namplate Capacity of Solar Farms per DNO in MW 2015



Pathway – Solar Farm to Consumer




Calculation of Solar Farm Output Data

Output for any solar farm anywhere in the UK

Start

Kriging of Met. Office Data: 80 weather stations

UK-Wide Map of Global Horizontal Irradiation



Available Data: Capacity and Location
Assumptions: Inclination angle 22°, Orientation: South, Module type: c-Si

Separation:
BRL model

2

Translation:
Hay & McKay with
Reindl's correction

3

Global Horizontal Irradiance + time/date
+ lat/long + Tilt + Azimuth
= Tilt Irradiation



Plane-of-array irradiance for each solar farm

Finish

5

King model for the maximum power point $P(G,T)$ with adjusted coefficients

4





Ross thermal model



Models that take as input irradiance and temperature (the only available information)

Calculated Solar Farm Generation


Performance Per DNO Modelled Output 2014 MWh




Monthly Variation in Output

Monthly Output 2014


- Monthly DC Output MWh per DNO
- 452 systems 1-50 MW
- Background – darker blue more systems
- Graph max. 160K MWh



Normalised UK Average Monthly kWhour/kWpeak 2005-2014







UK Average Hourly kWhour/kWpeak 2005-2014



Solar Farms Production and Demand per DNO


Modelled Output 2014 MWh





Demand
2015 MWh
Electricity
Ten Year
Statement
2015

Consumption profile in 2015 (from DECC)

Annual Solar farm output
allocated to substation 2014 MW
(circles)



Annual Substation
demand 2015 (triangles)
MW




*Demand highest in:
London, Coventry,
Birmingham, Leicester,
Nottingham, Leeds,
Sheffield, Manchester,
Newcastle. Completely
incompatible with
supply.*

Case Studies of Constraints

Large offshore wind farm

UK National Grid Voltage Layers




Case Study One

Case Study Two

Case Study One

22 solar farms, totalling 215 MW feeding into 1200 MW (5 x 240 MW) Station.

Even if it all goes through one Grid Supply Point (240 MW) it won't overload.



Constraints: Case Study Two


Bulk Supply Points 132 kV in Southern DNO

Note: Southern has:
37 Grid Supply Points
77 Bulk Supply Points ∴
smaller areas

- Diane: 3 constrained
- SSEDP: 39 constrained
- 2 agree, 1 disagree

Constraints:
Red - constrained
Green - Unconstrained
Circles – SSEPD
Stars - Diane

1. Calculate capacity of solar farms feeding in.
2. Subtract minimum demand from this to give net capacity.
3. If greater than transformer rating, then overloaded.



When Do Solar Farms Achieve Full Capacity? Theoretically

Compute the solar position and intensity from time and place

Model 1:

Standard Test Conditions i.e. 1000 watts of sunlight per square meter of horizontal surface

| | April | May | June | July | Aug |
|----------|-------|-----|------|------|-----|
| 10:00 AM | | | | | |
| 11:00 AM | | | | | |
| 12:00 PM | | | | | |
| 1:00 PM | | | | | |
| 2:00 PM | | | | | |

515 hours

5.88% of all hours

Model 2:


Tilt 22 degrees, South-facing > 1130 kWh/sqm

| | March | April | May | June | July | Aug | Sept |
|----------|-------|-------|-----|------|------|-----|------|
| 10:00 AM | | | | | | | |
| 11:00 AM | | | | | | | |
| 12:00 PM | | | | | | | |
| 1:00 PM | | | | | | | |
| 2:00 PM | | | | | | | |


806 hours

10% of all hours

Achievement of Nameplate Capacity: Actually



% of Daylight Hours more than 90% capacity achieved
2014




No more
than 93%
capacity
ever
achieved

NB. Oversizing:
Ratio of array
nameplate
capacity at STC
to inverter's
rated AC output
e.g. 1:25



Effect of Overplanting / Power Limiting e.g. 6MW Inverter for 10MW Nameplate Capacity Solar Farm

Hourly Output 2014 for 10MW Solar Farm in Cornwall




Two Scenarios . . .

Hourly Output for 2015 for Two Solar Farms in Cornwall:

Orange Farm: 10MW Capacity, 6MW inverter

Green Farm: 6MW Capacity, 6MW inverter



Oversizing capacity to inverter ratio

- Matching inverter to capacity maximises energy harvest of each module in the system. Inverter spends little time power limiting (“clipping”).
- BUT
- Oversized inverter gives greater annual yield.
- Solar farms are required to state the maximum impact on the grid – no requirement to give details of oversizing.
- Some don’t oversize at all.
- Some oversize by 40%.
- The stated capacity in the Renewable Energy Planning database can be either – *we don’t know*.

Summary and conclusions

- Demand and Production not well balanced for solar farms.
- Plenty of Capacity on Grid (for PV).
- Achievement of full capacity:
 - Theoretically 10% of hours could have full capacity.
 - Modelling of nameplate capacity gave 0% for 2014.
 - Due to overplanting will be somewhere in between e.g. 5% of hours when down-regulation potentially required – very little impact.
 - We don't know how much overplanting there is would be interested to find out.
- Maximum capacity / yield occurs at predictable times (middle of the day, March-Sept).
- No perceived threat to grid stability at the present time.

