

Article

Evaluation Method for the Hourly Average CO_{2eq} Intensity of the Electricity Mix and Its Application to the Demand Response of Residential Heating

John Clauß ^{1,*}, Sebastian Stinner ¹, Christian Solli ², Karen Byskov Lindberg ^{3,4}, Henrik Madsen ^{5,6} and Laurent Georges ^{1,6}

¹ Norwegian University of Science and Technology NTNU, Department of Energy and Process Engineering, Kolbjørn Hejes vei 1a, 7491 Trondheim, Norway; sebastian.stinner@rwth-aachen.de (S.S.); laurent.georges@ntnu.no (L.G.)

² NTNU, Property Division, Høgskoleringen 8, 7034 Trondheim, Norway; christian.solli@ntnu.no

³ NTNU, Department of Electric Power Engineering, 7491 Trondheim, Norway; karen.lindberg@sintef.no

⁴ SINTEF Building and Infrastructure, Pb 124 Blindern, 0314 Oslo, Norway

⁵ DTU Technical University of Denmark, DTU Compute, Asmussens Allé, Building 303B, 2800 Kgs. Lyngby, Denmark; hmad.dtu@gmail.com

⁶ Research Center on Zero Emission Neighbourhoods in Smart Cities, Trondheim 7491, Norway

* Correspondence: john.clauss@ntnu.no

Received: 1 March 2019; Accepted: 2 April 2019; Published: 8 April 2019



Abstract: This work introduces a generic methodology to determine the hourly average CO_{2eq} intensity of the electricity mix of a bidding zone. The proposed method is based on the logic of input–output models and avails the balance between electricity generation and demand. The methodology also takes into account electricity trading between bidding zones and time-varying CO_{2eq} intensities of the electricity traded. The paper shows that it is essential to take into account electricity imports and their varying CO_{2eq} intensities for the evaluation of the CO_{2eq} intensity in Scandinavian bidding zones. Generally, the average CO_{2eq} intensity of the Norwegian electricity mix increases during times of electricity imports since the average CO_{2eq} intensity is normally low because electricity is mainly generated from hydropower. Among other applications, the CO_{2eq} intensity can be used as a penalty signal in predictive controls of building energy systems since ENTSO-E provides 72 h forecasts of electricity generation. Therefore, as a second contribution, the demand response potential for heating a single-family residential building based on the hourly average CO_{2eq} intensity of six Scandinavian bidding zones is investigated. Predictive rule-based controls are implemented into a building performance simulation tool (here IDA ICE) to study the influence that the daily fluctuations of the CO_{2eq} intensity signal have on the potential overall emission savings. The results show that control strategies based on the CO_{2eq} intensity can achieve emission reductions, if daily fluctuations of the CO_{2eq} intensity are large enough to compensate for the increased electricity use due to load shifting. Furthermore, the results reveal that price-based control strategies usually lead to increased overall emissions for the Scandinavian bidding zones as the operation is shifted to nighttime, when cheap carbon-intensive electricity is imported from the continental European power grid.

Keywords: predictive rule-based control; hourly CO_{2eq} intensity; demand response; energy flexibility

1. Introduction

A transition to a low-carbon energy system is necessary to reduce its environmental impact in the future. This implies a reduction of CO_{2eq} emissions on the electricity supply side by making use of intermittent renewable energy sources. To fully exploit the electricity generated from these

intermittent energy sources, deploying demand side flexibility is crucial [1]. Regarding building heating systems, demand side flexibility is the margin by which a building can be operated while still fulfilling its functional requirements [2]. From a global perspective, potential emission savings from the building sector are large since the building sector is responsible for 30% of the total energy use [3]. Several studies point out the importance of demand side management to improve the interaction between buildings and the electricity grid [1,4–8]. Progressively decreasing prices for sensing, communication, and computing devices will open up possibilities for improved controls for demand response (DR) as future management systems will be more affordable. A number of studies have investigated the building energy flexibility with a special focus on building heating systems [9–16]. In those studies, DR measures have been applied to electric heating systems, such as heat pump systems or direct electric heating systems.

DR measures can be applied to control the electricity use for the heating of buildings depending on power grid signals [12]. The most common signal for DR is the electricity spot price [15–20], but the $\text{CO}_{2\text{eq}}$ intensity of the electricity mix [15,21–25], the share of renewables in the electricity mix [9,26] or voltage fluctuations [27] are applied as well.

DR measures are implemented into control strategies, such as predictive rule-based controls (PRBC) or more advanced controls, e.g., optimal control or model-predictive controls (MPC). PRBCs rely on pre-defined rules to control the energy system, where temperature set-points (TSP) for space heating (SH) or domestic hot water (DHW) heating are usually varied to start or delay the operation of the heating system depending on the control signal. These rules are rather straightforward to implement, but a careful design of the control rules is necessary. MPC solves an optimization problem but is more expensive to develop, for instance the identification of a model used for control is acknowledged as the most critical part in the design of an MPC [28,29]. PRBCs can be a good compromise to advanced controls because PRBC is simpler, but can still be effective in reducing operational costs or saving carbon emissions [29].

By applying the carbon intensity as a penalty signal for indirect control, the operation of a heating system can be shifted to times of low $\text{CO}_{2\text{eq}}$ intensity in the grid mix using thermal storage. In general, the $\text{CO}_{2\text{eq}}$ intensity can be used as an indicator of the share of renewable energies in the electricity mix. Applying the $\text{CO}_{2\text{eq}}$ intensity as a penalty signal to operate building energy systems can help to reach the emission targets of the European Union. In Norway, electricity is mostly generated from hydropower. However, an increased interaction between the continental European and the Norwegian power grids is expected in the future [30]. As Norway has a very limited number of fossil fuel power plants for electricity generation, the hourly average $\text{CO}_{2\text{eq}}$ intensity of the electricity mix already strongly depends on the electricity exchanges with neighboring bidding zones (BZ). Generally, the CO_2 price is seen as an essential driver for the transition to a low-carbon society [30]. This CO_2 price is expected to increase in the future so that the application of a $\text{CO}_{2\text{eq}}$ intensity signal for control purposes is likely to gain importance. Compared to the electricity spot price, the use of the $\text{CO}_{2\text{eq}}$ intensity of the electricity mix as a control signal is not as common because this control signal is not readily available. To the author's knowledge, in Europe, only the transmission system operator (TSO) for Denmark, Energinet, provides information on the average $\text{CO}_{2\text{eq}}$ intensity of the electricity mix with an hourly resolution and at no charge. This may also be the reason why most studies that use $\text{CO}_{2\text{eq}}$ intensity as a penalty signal for heating were performed for Denmark and conducted only rather recently: Vogler-Finck et al. [21], Pedersen et al. [22], Hedegaard et al. [23], and Knudsen et al. [24] use the data from Energinet in their DR studies for the heating of residential buildings.

The European power grid is highly interconnected. The leading power market in Europe is NordPool, which provides a day-ahead as well as an intra-day market. NordPool mainly operates in Scandinavia, UK, Germany, and the Baltics [31]. It is owned by the Scandinavian TSOs (Norway, Sweden, Denmark, and Finland) and the Baltic TSOs (Estonia, Lithuania, and Latvia) [32]. In order to avoid bottlenecks in the transmission system, BZs are created with different electricity prices.

One country can have several BZs [33]. Norway consists of five BZs, each of them having physical connections to neighboring BZs that enables electricity imports and exports (Figure 1).




Figure 1. Overview of the Scandinavian power market bidding zones, also including gas-fired power plants in Norway (adjusted from [30]).

The main contributions of this paper are twofold. Firstly, a methodology for calculating the hourly average $\text{CO}_{2\text{eq}}$ intensity of the electricity mix in an interconnected power grid is developed. The methodology is generic and takes into account the hourly average $\text{CO}_{2\text{eq}}$ intensities of the electricity traded between neighboring BZs (imports and exports). The proposed method resorts to the logic of multi-regional input–output models (MRIO) [34]. Input–output models are usually used to perform energy system modeling in combination with an economic analysis considering different industry sectors [35–37]. They are based on the assumption that there always is a balance between consumption and generation for the whole system. In the present work, this logic can be applied for electricity where BZs are used instead of industry sectors. As an example, this paper evaluates the hourly average $\text{CO}_{2\text{eq}}$ intensity for several Scandinavian BZs using the electricity production data for the year 2015. Emissions related to an electricity generation technology are considered on a life-cycle perspective. Electricity losses in the transmission and distribution grid are neglected. The input data required to calculate the average $\text{CO}_{2\text{eq}}$ intensity is not readily available. Therefore, this work does not only provide the methodology to determine the $\text{CO}_{2\text{eq}}$ intensities but also guidelines on where to retrieve and how to structure the input data to apply the proposed methodology.

Secondly, studies that focus on the evaluation of hourly $\text{CO}_{2\text{eq}}$ intensities usually do not consider the detailed control of the HVAC system, whereas most studies that specifically focus on the heating system control do not comment on the methodology for determining the $\text{CO}_{2\text{eq}}$ intensity. Therefore, the paper investigates how the characteristics of the $\text{CO}_{2\text{eq}}$ intensity used as control signal influence

the overall emission savings. This is done using the case study of residential heating where DR is performed using the CO_{2eq.} intensity of several Scandinavian BZs. A detailed description of the HVAC system and its control is provided which has been spotted as a major short-coming of the other existing approaches that primarily focus on the CO_{2eq.} intensity evaluation.

2. Review of Existing Evaluation Methods for CO_{2eq.} Intensity

Generally, evaluation methods for the hourly CO_{2eq.} intensities of the electricity mix can be categorized as presented in Table 1. In a de-coupled approach, the electricity demand and supply sides do not influence each other. On the contrary, in a coupled approach, the interaction between the demand and supply sides is taken into account. For example, if a large number of buildings would apply the average CO_{2eq.} intensity as a penalty signal, the resulting electric load could be affected and thus the predicted generation would not be optimized for this load anymore. Ideally, a coupled approach should be used to take into account DR in the prediction of the electricity generation and the respective CO_{2eq.} emissions [26,38,39]. Furthermore, average and marginal CO_{2eq.} intensities are two distinct concepts. Marginal emissions are the emissions from one additional kWh generated/consumed and, consequently, it results from a single power plant. On the contrary, the average CO_{2eq.} intensity is the CO_{2eq.}/kWh emitted on average from the entire electricity generation of the BZ. It thus results from a mix of power plants. On the one hand, it could be argued that the marginal CO_{2eq.} intensity is most coherent for the control of a limited number of buildings because they will rather affect a single plant than the overall production. On the other hand, average CO_{2eq.} intensities (or factors) have been used extensively in the past for buildings exporting electricity to the grid, e.g., Zero Emission Buildings or Nearly Zero Energy Buildings. Studies mostly focusing on the life-cycle assessment (LCA) of buildings often use average CO_{2eq.} intensities rather than marginal intensities.

Table 1. Categorization of methodologies to evaluate CO_{2eq.} intensities of the electricity mix (marked as 'CO₂') or determine the optimal dispatch and unit commitment in electricity grids (marked as 'EL').

De-Coupled Approach		Coupled Approach	
Average	Marginal	Average	Marginal
Energinet [40] (CO ₂)	Bettle et al. [44] (CO ₂)		Patteeuw et al. [26] (EL)
Vandermeulen et al. [9] (CO ₂)	Hawkes [45] (CO ₂)		Arteconi et al. (based on Patteeuw) [38] (EL)
Milovanoff et al. [41] (CO ₂)	Peán et al. (based on Hawkes) [25] (CO ₂)	Graabak [47] (CO ₂)	Graabak et al. [47] (CO ₂ , EL)
Roux et al. [42] (CO ₂)	Corradi [46] (CO ₂)		Askeland et al. [48] (EL)
Tomorrow [43] (CO ₂)			Quoilin et al. [49] (EL)

2.1. De-Coupled Approach

The evaluation methodology of the TSO Energinet for determining the CO_{2eq.} intensity of the Danish electricity mix has two distinct simplifications: (1) the methodology considers only the operational phase (meaning without the life-cycle perspective) and (2) the CO_{2eq.} intensity of the imports from neighboring countries are assumed to be constant. For example, electricity imports from Norway are assumed to be 9 g/kWh, from Germany 415 g/kWh and from Sweden 28 g/kWh [40].

Vandermeulen et al. [9] aim at maximizing the electricity use of residential heat pumps at times of high shares of renewable energy generation in the Belgian power grid. Data from the Belgian TSO, Elia, is used. It is not stated whether electricity imports are considered.

Milovanoff et al. [41] determine the environmental impacts of the electricity consumption in France for the years 2012 to 2014. They calculate 'impact factors' for electricity generation and consumption, where the impact factor for consumption agrees with the environmental impacts per kWh consumed including country-specific electricity production and trades. Regarding the electricity trades with neighboring BZs, it is assumed that the impact of the electricity imports to France equals the impact of the electricity generated in the BZ France is importing from, without taking exports and imports between France' neighboring BZs into account. Even though the methodology does not take

into account the electricity trades between neighboring BZs, it is pointed out that dynamic data of electricity imports and exports should be considered for calculating $\text{CO}_{2\text{eq}}$ intensities of the electricity consumption. Milovanoff et al. as well as Roux et al. [42] make use of the Ecoinvent data base version 3.1 which provides CO_2 factors for electricity generation technologies considering the whole life-cycle of a technology. Roux et al. calculate hourly average $\text{CO}_{2\text{eq}}$ intensities of the electricity generation and consumption in France for the year 2013. Their study focuses on the magnitude of errors when a yearly-average factor for the electricity mix is used instead of an hourly-average factor varying throughout the year. However, it is not stated how the $\text{CO}_{2\text{eq}}$ intensities of the imports are considered in the study.

The company Tomorrow launched a website which shows the hourly average $\text{CO}_{2\text{eq}}$ intensity for most European countries in real time [50]. Data on the electricity generation per production technology in a BZ is taken from ENTSO-E. Furthermore, trading between BZs as well as time-varying $\text{CO}_{2\text{eq}}$ intensities are considered in their models (Tomorrow, 2018), but a license has to be purchased to get access to the data. Their method is based on the electricity balance between the supply and demand side. The hourly $\text{CO}_{2\text{eq}}$ intensities of each BZ are considered as vectors in a linear equation system, which is solved for the $\text{CO}_{2\text{eq}}$ intensity for each hour of year.

Bettle et al. [44] calculate marginal emission factors for Wales and England for the year 2000, based on 30 min data of a full year for all generating power plants considering all plants individually. Imports are not considered in their study. They found that the marginal emission factor is usually higher than the average emission factor (up to 50% higher). Thus, the average factor is likely to underestimate the carbon-savings potential.

Hawkes [45] estimates marginal CO_2 emission rates for Great Britain, based on data from 2002 to 2009. The emission rate is termed marginal emission factor and corresponds to the CO_2 intensity of the electricity not used as a result of a DR measure. The approach follows a merit-order approach and thus applies only to countries where the electricity generation is primarily based on fossil-fuel technologies. The methodology does not consider electricity imports from neighboring BZs. They point out a clear correlation between the total system load and the marginal emission factor, showing high emission factors during times of high system loads.

Peán et al. [25] determine marginal emission factors for Spain for the year 2016 based on the methodology proposed by Hawkes [45]. Similar to Hawkes, electricity imports are not considered.

Corradi [46] aims at calculating the marginal $\text{CO}_{2\text{eq}}$ intensity of the electricity using machine learning. Flow tracing [51] is used to trace the flow of the electricity back to the area where the marginal electricity is generated. Following Corradi's approach, in the end, the total marginal emissions of a BZ are the weighted average of the emissions from the marginal electricity generation plant of that BZ and the marginal electricity generation plant of the imports (in case of imports), using the percentage of origin as a weight.

2.2. Coupled Approach

Graabak et al. [47] determine yearly average marginal emission factors for the European power grid and marginal emission factors for the Norwegian power grid based on a European Multi-area Power-market Simulator (EMPS). EMPS is a stochastic optimization model for hydro-thermal electricity markets where the electricity market is arranged so that electricity prices balance supply and demand in each area and time step. It is used by all main actors in the Nordic power market, such as the TSOs, and for energy system planning, production scheduling, and price forecasting. Average emission factors are estimated for several scenarios of production portfolio for the European power grid. They point out that an average emission factor should be used for the control of a large number of buildings while a marginal emission factor should be applied for the control of a limited number of buildings.

Patteeuw et al. [26], Arteconi et al. [38], Askeland et al. [48] and Quoilin et al. [49] determine optimal dispatch and unit commitment in electricity grids. None of the models calculates $\text{CO}_{2\text{eq}}$ intensities. Nevertheless, their models could determine the carbon intensity by considering CO_2 factors for each

electricity generation technology. Patteeuw et al. [26] developed an approach to model active demand response with electric systems while considering both the supply and demand sides. The model takes thermal comfort and techno-economic constraints of both sides of the power system into account. Formulated as an optimization problem, it minimizes the overall operational cost of the electricity generation. The case study is based on the Belgian power system using the year 2010. This model enables to investigate the influence of different levels of market penetration of DR on the decision of the marginal generation technology. The approach does not consider imports. Arteconi et al. [38] apply the same model for the choice of the generation technology and use a low-order resistance–capacitance building model as a case study to investigate the DR potential of a building.

Askeland et al. [48] developed an equilibrium model for the power market that couples the demand and supply sides. The model provides time series for the electricity demand as well as for the renewable energy generation. A case study for the Northern European power system is performed where the effect of DR on the potential shift in the generation mix is studied. Quoilin et al. [49] developed a model called Dispa-SET, which is an open-source model that solves the optimal dispatch and unit commitment problem at the EU level, applying one node per country, instead of per BZs.

3. Evaluating the Hourly Average CO_{2eq} Intensity

In the following, the sources for required input data are first presented. The assumptions for processing the data are then stated. Finally, a step-by-step guidance is given to determine the hourly average CO_{2eq} intensity of the electricity mix per BZ. In the case study, hourly average CO_{2eq} intensities are calculated for Scandinavia, meaning Norwegian, Swedish, and Danish bidding zones, but also for Finland, Germany, and the Netherlands.

3.1. Data Retrieval and Pre-Processing

3.1.1. Electricity Use per Bidding Zone

Data regarding the electricity generation per production type within a BZ can be retrieved from ENTSO-E, which is the European Network of TSOs for Electricity. The European TSOs are supposed to provide data to ENTSO-E to promote market transparency and closer cooperation across the TSOs. A free user account at ENTSO-E has to be set up to download the data. Furthermore, data may also be retrieved directly from national TSOs, if the dataset from ENTSO-E is incomplete for specific BZs. For instance, hourly electricity generation data for the Swedish BZs was here obtained from the Swedish TSO (as this data was not available from ENTSO-E).

The ENTSO-E dataset contains hourly values for the total electricity generated per production type within a BZ. Thermal power plants are included as a production type. In practice, these power plants can consume most of the generated electricity onsite. Therefore, it is necessary to have knowledge about the sales licenses to the grid of these power plants. When onsite-generated electricity is not sold to the grid, it should ideally not be considered for the average CO_{2eq} intensity of the electricity mix. Information regarding sales licenses can usually be obtained from either the TSO, state directorates or directly from the company owning the power plant. For our case study of Scandinavia, these sales licenses were only determined for Norway. The Norwegian thermal power plants with the highest installed capacities are shown in Figure 1. Only the power plant of Mongstad sells electricity to the grid. Comprehensive information on data treatment and assumptions is provided in [39].

The input data can be arranged in the following way:

$$BZ = \begin{bmatrix} P_{BZ_j,EGT_1}(t_1) & \cdots & P_{BZ_j,EGT_m}(t_1) \\ \vdots & \ddots & \vdots \\ P_{BZ_j,EGT_1}(t_g) & P_{BZ_j,EGT_i}(t_g) & \vdots \\ \vdots & \vdots & \ddots \\ P_{BZ_j,EGT_1}(t_{8760}) & \cdots & P_{BZ_j,EGT_m}(t_{8760}) \end{bmatrix} \quad (1)$$

where

- i is the “index of EGTs” ranging from 1 to m
- j is the “index of a specific BZ”
- g is the “hour of the year” ranging from 1 to 8760 (or 8784)

The matrix BZ (where ‘BZ’ stands for bidding zone) includes the electricity generation from each electricity generation technology (EGT_i) at every hour of the year (t_g). EGT_i represents electricity generation from each technology in the BZ, but, by extension, it also includes the imports from first tier BZs. In other words, imports from other BZs are considered as an EGT in the matrix.

3.1.2. Emission Factors per Electricity Generation Technology

The average CO_{2eq} intensity of a BZ depends directly on the CO_2 factor that is associated to each EGT. This choice of the CO_2 factor strongly affects the final result of the evaluation. Two possible ways of acquiring CO_2 factors of a given EGT are the IPCC report [52,53] or the Ecoinvent database [54]. Ecoinvent provides a vast variety of CO_2 factors for electricity generation from a given fuel type depending on the type of power plant and the specific country. A license is necessary to use Ecoinvent, whereas the IPCC report is available free of charge. CO_2 factors can differ between references mainly due to different allocations of emissions, especially for combined heat-and-power plants. More detailed information regarding emission allocations are given in [52–54]. Regarding annual average CO_{2eq} intensities of a country (see Table A1 in Appendix A), they can be calculated from Ecoinvent or taken from the website of the European Environment Agency [55].

For the sake of the simplicity, our case study considers a same CO_2 factor per EGT for every country. Therefore, it assumes that the CO_2 factor is independent of the country and the specific power plant as long as it uses the same EGT (disregarding the thermal efficiency or the age of the power plant). The proposed methodology is however more general. If a different CO_{2eq} factor should be considered for a same EGT but for a different plant efficiency, plant age, or country, a new EGT should be defined for each different CO_{2eq} factor considered.

In this study, data from the Ecoinvent database has been used. The phases that were considered in the CO_2 factor per EGT are the extraction of fuels, the construction of the power plant (including infrastructure and transport), its operation and maintenance as well as the end of use of the power plant. The CO_2 factor for hydro pumped storage is here assumed constant in time, 62 gCO_{2eq}/kWh . In fact, it is dependent on the CO_{2eq} intensity of the electricity mix used when pumping water into the storage reservoir. Unlike Norway, this assumption can be critical for BZs that usually have a relatively high CO_{2eq} intensity. Strictly speaking, if the constant CO_2 factor considered for hydro pumped storage is much lower than the CO_{2eq} intensity of the electricity mix when water is pumped into the storage, it would correspond to a ‘greenwashing’ of the electricity mix. Furthermore, ENTSO-E defines an EGT category called ‘other’ with no further specifications. It is thus difficult to allocate a CO_2 factor for this production type and it could also differ among different countries. In this work, the factor is assumed to be the average of the fossil fuel technologies. Table A1 gives an overview of typical CO_2 factors for different fuel types.

3.2. Calculation Methodology

The electricity mix is assumed homogeneous in each BZ, meaning that a same CO_{2eq} intensity is used for the entire BZ at each hour of the year. For neighboring countries where the CO_{2eq} intensities are not evaluated (here called 'boundary BZ'), a yearly-averaged CO_{2eq} intensity is considered. In our case study, these countries are Great Britain, Belgium, Poland, Estonia, and Russia. It is nonetheless reasonable to assume that they have a limited impact on the Norwegian electricity mix. They are either 2nd tier countries (i.e., which do not have a direct grid connection to Norwegian BZs) or have limited electricity export to Norway (which is typically the case for Russia). By extension, BZs for which the average CO_{2eq} intensity is calculated for every hour of the year are hereafter called computed BZs.

Matrix $T(t)$ (where 'T' stands for technology) includes the electricity generation from all EGTs in all BZs and is calculated for each hour of the year (t):

$$T(t) = \begin{bmatrix} P_{BZ_1,EGT_1}(t) & \cdots & P_{BZ_n,EGT_1}(t) \\ \vdots & \ddots & \vdots \\ P_{BZ_1,EGT_m}(t) & \cdots & P_{BZ_n,EGT_m}(t) \end{bmatrix} \quad (2)$$

where

- i is the "index of EGTs" ranging from 1 to m
- j is the "index of BZs" ranging from 1 to n

The size of matrix $T(t)$ depends on the number of EGTs and number of BZs that are considered in a respective study.

The next step is a normalization to 1 MWh by dividing by the total hourly electricity generation (i.e., summing on all the EGT_i , also considering imports) in a bidding zone (BZ_j) during each hour (t) of the year. This step will be necessary to determine the CO_{2eq} intensity for 1 MWh of generated electricity in a respective BZ. Matrix $N(t)$ (where 'N' stands for normalization) is set up as follows:

$$N(t) = \begin{bmatrix} \frac{1}{\sum_i P_{BZ_1,EGT_i}(t)} & 0 & 0 & 0 & 0 \\ 0 & \ddots & 0 & 0 & 0 \\ 0 & 0 & \frac{1}{\sum_i P_{BZ_j,EGT_i}(t)} & 0 & 0 \\ 0 & 0 & 0 & \ddots & 0 \\ 0 & 0 & 0 & 0 & \frac{1}{\sum_i P_{BZ_n,EGT_i}(t)} \end{bmatrix} \quad (3)$$

where

- i is the "index of EGTs" ranging from 1 to m
- j is the "index of a specific BZ" ranging from 1 to n

The matrix $P(t)$ (where 'P' stands for production) is the share of each EGT on the total hourly electricity generation in a respective BZ, still considering electricity imports as an EGT. Regarding the electricity imports to a BZ, it is distinguished between imports from boundary BZs with a fixed CO_{2eq} intensity of the electricity mix ($P_{Import,fix,t}$) and imports from computed BZs with a variable electricity mix ($P_{Import,var,t}$). At this stage, $P(t)$ only considers the share of each EGT in the electricity mix of a

specific BZ, but does not consider the share of each EGT in the imports. $P(t)$ is calculated by multiplying $T(t)$ and $N(t)$. The share of EGTs (located inside the BZ j) in the generation mix is called $P_{EGT,t}$.

$$P(t) = T(t) \cdot N(t) = \begin{bmatrix} P_{EGT,t} \\ P_{Import,fix,t} \\ P_{Import,var,t} \end{bmatrix} \quad (4)$$

$P_{EGT,t}$ and $P_{Import,fix,t}$ can be combined to define the matrix $P_{EGT,fix}$:

$$P_{EGT,fix} = \begin{bmatrix} P_{EGT,t} \\ P_{Import,fix,t} \end{bmatrix} \quad (5)$$

The next steps show how to include the share of each EGT in the electricity imports; in other words, how the electricity mix of a neighboring BZ influences the electricity mix of a BZ through imports. In general, the balance between electricity consumption and electricity generation has to be satisfied at all times for each BZ. This idea is further generalized in MRIO models, where interdependencies within the whole system can be captured, while preserving regional differences [56]. For each BZ, the sum of electricity import and generation by a specific EGT should be consumed in the BZ, or exported. This complies with the logic of MRIO models which can be used to calculate consumption-based emissions for an entire country or region [34]. The electricity balance can then be expressed as

$$M = P_{EGT,fix} + M \cdot P_{Import,var,t}, \quad (6)$$

with M (where ' M ' stands for mix) representing the share of each EGT on the electricity use of BZ_j and the exports from BZ_j . Solving Equation (6) for M is done by

$$M(i, j) = P_{EGT,fix} \cdot (I - P_{Import,var,t})^{-1}. \quad (7)$$

where I is an identity matrix. Matrix $M(i, j)$ contains the share of each EGT_i (and boundary BZ) on the electricity use and exports from BZ_j . A new matrix is computed for each hour of the year.

The average CO_{2eq} intensity of a BZ for every hour of the year is calculated by

$$e_j(t) = \sum_{i=1}^m e_{f_{EGT_i}} \cdot M(i, j) \quad (8)$$

where t is the hour of the year, i is the index of the EGT ranging from 1 to m , j is the index of a specific BZ ranging from 1 to n and $e_{f_{EGT_i}}$ is the emission factor of the EGT of index i .

3.3. Applicability of the Methodology

Comparing the proposed methodology with the other existing methodologies presented in Table 1, its major advantage is its simplicity. Nevertheless, it also has limitations. As a decoupled approach, the method can be used as long as the number of buildings participating in DR schemes is low; in other words, as long as the level of the market penetration of DR in buildings is still limited. This limitation counts for all decoupled approaches, not only for the proposed method. Furthermore, this approach is representative for most simulation-based studies in building energy flexibility. Yearly average CO_{2eq} intensities of the electricity mix have been used extensively in the past to calculate the emission balance of buildings that export electricity to the grid [57]. Studies mostly focusing on the LCA of buildings often use average CO_{2eq} intensities rather than marginal intensities. The use of hourly average CO_{2eq} intensities as a control signal for DR is thus remaining coherent with that approach. Also, in the EPBD method, average primary energy factors are often used to evaluate the performance of buildings.

3.4. CO_{2eq} Intensities in Scandinavian Bidding Zones

As a case study, the hourly average CO_{2eq} intensities for all Norwegian BZs are evaluated for the year 2015. Results are plotted in Figure 2a. NO5 has the highest annual average CO_{2eq} intensity which is due to the electricity generation from the thermal power plant in Mongstad (see Figure 1 and Table 2). Furthermore, it is obvious that the highest CO_{2eq} intensity peaks occur in NO2. Figure 2b presents the average CO_{2eq} intensities for NO2, NO3, SE1, SE4, DK1, and FIN. It is clear that the Norwegian electricity mix has low average CO_{2eq} intensities compared to non-Norwegian BZs. Resulting from the large differences in CO_{2eq} intensity, the average CO_{2eq} intensity in NO2 usually increases when electricity is imported from DK1, which also explains the CO_{2eq} peaks in the BZ. The impact of fossil fuel-based electricity imports on the average CO_{2eq} intensity is particularly strong for the case of Norway because the electricity generation in Norway is almost entirely from hydropower. The impact of carbon-intensive electricity imports on the average CO_{2eq} intensity of other countries, like Finland or Denmark, is usually lower. A more detailed analysis of the correlation of the average CO_{2eq} intensity and electricity imports to Norway is provided in [39].




Figure 2. Hourly average CO_{2eq} intensity of the electricity mix for (a) the Norwegian bidding zones and (b) for several Scandinavian bidding zones.

Table 2. Comparison of the annual average CO_{2eq.} intensities of the electricity mix for several Scandinavian bidding zones.

BZ	NO1	NO2	NO3	NO4	NO5	SE1	SE4	DK1	FIN
Average CO _{2eq.} intensity (gCO _{2eq.} /kWh)	15	17	11	9	20	21	114	316	227
Average CO _{2eq.} intensity without imports (gCO _{2eq.} /kWh)	7	8	8	7	20	21	259	461	241

An overview of the annual average CO_{2eq.} intensities is provided in Table 2. DK1 has the highest annual average CO_{2eq.} intensities, followed by FIN and SE4.

Figure 3 illustrates the relation between the average CO_{2eq.} intensity and the electricity spot price for six Scandinavian BZs for an exemplary five-day period. For the Norwegian BZs NO2 and NO3 (see Figure 3a,b) it is shown that the average CO_{2eq.} intensity is low, when the electricity spot price is high. In Norway, electricity is produced from hydropower in times of high demands. Electricity spot prices are high during high electricity demands, thus typically leading to low CO_{2eq.} intensities. In general, the Norwegian hydropower reservoirs are operated in a cost-optimal way, so that electricity is imported during the night when electricity is cheap and exported to continental Europe during the day, when electricity is expensive [39]. This operation strategy can also be used to explain the CO_{2eq.} intensities in the BZs shown in Figure 3. The correlation between the carbon intensity and the spot price for the Swedish BZs is similar to the Norwegian BZs.

SE1 (Figure 3c) is the northernmost Swedish BZ and relies primarily on electricity generation from hydro reservoirs and on-shore wind as well as on electricity imports from SE2. Thus, average CO_{2eq.} intensities are generally rather low. Regarding the correlation with electricity spot prices, CO_{2eq.} intensities are low when spot prices are high. This relation is also similar for SE4 (see Figure 3d) but to a lower extent. The average CO_{2eq.} intensities in SE4 are several times higher compared to SE1 because SE4 trades a lot of electricity with Denmark, Poland, and Germany.

A rather weak correlation between the carbon intensity and the spot price can be seen for DK, which is in accordance with the findings from Knudsen et al. [24] who found that a low CO_{2eq.} intensity does not necessarily occur concurrent with low costs. A difference between day and night is also visible for the CO_{2eq.} intensity in DK1. A correlation between the carbon intensity and the spot price on an hour-by-hour basis is not obvious because the CO_{2eq.} intensity varies much faster than the spot price. A clear relationship between the CO_{2eq.} intensity and the spot price is not visible for FIN.




Figure 3. Average CO_{2eq} intensity and spot prices for five exemplary days in 2015 for six Scandinavian BZs: (a) NO₂, (b) NO₃, (c) SE1, (d) SE4, (e) DK1, and (f) FIN.

4. Case Study Using Demand Response for Heating

4.1. Case Building

To represent a large share of the Norwegian residential building stock, a single-family detached house built according to the building standard from the 1980s, TEK87, is chosen as a case [58]. The geometry of the building is based on the ZEB Living Lab which is a zero emission residential building located in Trondheim [59]. The envelope model of the real Living Lab has been calibrated with the help of dedicated experiments for the building performance simulation tool IDA ICE. However, the thermal properties of the building envelope for this case study comply with TEK87. The Living Lab has a heated floor area of 105 m², the floor plan being shown in Figure 4. An overview of the building properties is provided in Table 3. For the sake of the simplicity, natural ventilation, which

was usually applied in TEK87 buildings, is modeled as balanced mechanical ventilation with a heat recovery effectiveness η_{HR} of 0%. This study considers the U-values of the building walls, but it should be noted that the building insulation level [15] as well as the thermal capacity of a building [60–62] influences the flexibility potential. The climate of Trondheim is also relevant for Norway in general.




Figure 4. Floor plan of the studied building [15].

Table 3. Building envelope properties and energy system characteristics of the case study building (EW—external wall; IW—internal wall; n_{50} —air changes per hour at 50 Pa pressure difference; U_{Total} —the total U-value of the windows including the glazing and the frame; HR—heat recovery; ER—electric radiator; AHU—air handling unit; HDS—heat distribution system).

Symbol Unit	Building Envelope				Thermal Bridges	Infiltration	Windows	AHU	HDS	SH Needs
	U_{EW}	U_{IW}	U_{Roof}	U_{Floor}	W/(m ² ·K)	n_{50}	U_{Total} W/(m ² ·K)	η_{HR} %	ER W/m ²	kWh/m ²
	0.35	0.34	0.23	0.30	0.05	3.0	2.1	0	93	172

A detailed multi-zone model of the building is created using the software IDA ICE version 4.8, which is a dynamic building simulation software that applies equation-based modeling [63]. IDA ICE has been validated in several studies [64–68].

Electric radiators are used for SH as it is the most common space-heating system in Norwegian houses [69]. One electric radiator is placed in each room with a power equal to the nominal SH power of the room at design outdoor temperature (DOT) of $-19\text{ }^{\circ}\text{C}$. DHW is produced in a storage tank. An electric resistance heater with a capacity of 3 kW is used for DHW heating and is installed in the lower third of the tank. IDA ICE has a one-dimensional model of a stratified water tank that accounts for the heat conduction and convection effects in the tank. The DHW storage tank is here divided into four horizontal layers to account for stratification effects. The DHW storage volume is calculated by

$$V_{DHW} \cong S \cdot 65 \cdot n_{people}^{0.7} \quad [\text{litre}] \quad (9)$$

where S is the safety margin and n_{people} the number of occupants. S is set to 125% for a low number of people [70]. The charging of the DHW storage tank is controlled by two temperature sensors that are installed in the bottom and the top of the tank. The electric resistance heater starts heating as soon as the temperature in the upper part of the tank drops below the set-point and it continues until the set-point for the temperature sensor in the lower part of the tank is reached. The DHW start

temperature is called the DHW TSP here. The DHW stop temperature is always taken 3 °C above to start temperature.

The internal heat gains from electrical appliances, occupants and lighting are defined according to the Norwegian technical standard, SN/TS 3031:2016 [71]. The daily DHW profiles are taken from the same standard. Schedules for electrical appliances are also based on SN/TS 3031:2016, whereas the schedules for occupancy and lighting are taken from prEN16798-1 and ISO/FDIS 17772-1 standards [72,73]. The internal heat gains are distributed uniformly in space. All profiles presented in Figure A1 have an hourly resolution and are applied for every day of the year.

The energy flexibility potential is evaluated for four different PRBCs by comparing them to the reference scenario that applies constant TSPs for SH (21 °C) and DHW (50 °C). The TSP for the bathroom is 24 °C. All doors are closed at all times. DR measures are applied to the common rooms only (meaning the living room, kitchen, and living room north). All cases use the weather data of 2015 (retrieved from [74]) for Trondheim, independent of the BZ considered. NordPool provides hourly day-ahead spot prices for each bidding zone [75]. They are used as an input signal for the price-based control and to calculate energy costs for heating. An electricity fee for the use of the distribution grid is not considered in the cost evaluation.

4.2. Demand Response Strategies

The reference scenario, termed BAU (for business as usual), maintains constant TSPs for SH and DHW heating at 21 °C and 50 °C respectively. Using constant TSP is the most common way to control the heating system in Norwegian residential buildings. These TSPs are varied for the DR strategies. The DHW TSP can be increased by 10 K or decreased by 5 K depending on the control signal. The limit for DHW temperature decrease is chosen with regards to Legionella protection. Regarding SH, the TSPs are increased by 3 K or decreased by 1 K. According to EN15251:2007 [76] indoor temperatures between 20 °C and 24 °C correspond to a predicted percentage dissatisfied (PPD) < 10% and $-0.5 < PMV < +0.5$ in residential buildings for an activity level of 1.2 MET and a clothing factor of 1.0 clo.

The control signal for the CO₂-based control is determined based on two principles. The first principle, hereafter called CSC-a, aims at operating the energy system in times of lowest CO_{2eq.} intensities by increasing TSPs for SH and DHW during these periods. For Norway, this principle may in practice lead to extended periods with high TSPs because of the typical daily CO_{2eq.} intensity profile (Figure 3a,b). This may lead to an unnecessary increase in annual energy use for heating. Therefore, the second principle—hereafter called CSC-b—does not aim at operating the heating system during periods with the lowest carbon intensities but rather charges the storages just before high-carbon periods in order to avoid the energy use during these critical periods. Using CSC-b, the TSPs are increased for shorter time periods compared to CSC-a, thus improving the energy efficiency.

The carbon-based PRBC uses a 24 h sliding horizon to determine a high-CO_{2eq.} intensity threshold (HCT) and low-CO_{2eq.} intensity threshold (LCT). At each hour, the current CO_{2eq.} intensity (CI) is compared to these thresholds. Taking CI_{max} and CI_{min} as the maximum and minimum intensities for the next 24 h, LCT has been selected to $CI_{min} + 0.3 (CI_{max} - CI_{min})$ and HCT to $CI_{min} + 0.7 (CI_{max} - CI_{min})$. Regarding CSC-a, if the CO_{2eq.} intensity of the current hour is below the LCT, the TSPs are increased. If the current CO_{2eq.} intensity is above the HCT, the set-points are decreased to delay the start of the heating, whereas if the CO_{2eq.} intensity of the current hour is between the LCT and HCT, the TSPs remain equal to the reference scenario. Regarding CSC-b, the control signal is also determined based on the three price segments, as defined for CSC-a, but, additionally, the control considers if the current CO_{2eq.} intensity is increasing or decreasing with time. If the current CO_{2eq.} intensity is between the LCT and HCT and the CO_{2eq.} intensity increases in the next two hours, TSPs are increased. Both principles, CSC-a and CSC-b, are presented in Figure 5.




Figure 5. Principle of the determination of the carbon-based control signal according to (a) CSC-a and (b) CSC-b. (HTSP is high temperature set-points, RTSP is reference temperature set-points, LTSP is low temperature set-points).

The performance of the control with regards to emission savings is sensitive to the selection of thresholds, LCTs and HCTs. The influence of LCTs and HCTs on the number of hours per TSP-segment has been evaluated for BZ NO₃. An LCT of 30% and an HCT of 70% have been chosen for calculating the control signal. The LCTs and HCTs for the other five BZs considered in the simulation study are chosen so that the number of hours in the three respective segments is equivalent to the case of NO₃. An overview of the different scenarios is presented in Table 4. In fact, there is an optimum LCT and HCT for each BZ to minimize carbon emissions. However, in the case study, the two thresholds are rather chosen to have a similar number of hours in the respective TSP segments. This is done to investigate the influence of the CO_{2eq} intensity profile on the carbon emissions rather than optimizing the control principle thresholds.

Table 4. Influence of the low-carbon and high-carbon thresholds (LCT and HCT) on the number of hours per temperature set-point segment (LTSP—low-temperature set-points; RTSP—reference temperature set-points; HTSP—high temperature set-points).

	Thresholds Kept Constant					Adjusted Thresholds for Similar Segments						
	NO2	NO3	SE1	SE4	DK1	FIN	NO2	NO3	SE1	SE4	DK1	FIN
CSC-a												
LCT [%]	30	30	30	30	30	30	22	30	27	29.5	47	46
HCT [%]	70	70	70	70	70	70	68.5	70	66	68.5	81.5	82
LTSP [h]	1812	1886	1706	1814	2584	2439	1879	1886	1884	1878	1882	1881
RTSP [h]	1822	2219	2166	2236	2731	2930	2229	2219	2223	2223	2230	2245
HTSP [h]	5126	4655	4888	4710	3445	3391	4652	4655	4653	4659	4648	4634
CSC-b												
LCT [%]	30	30	30	30	30	30	22	30	27	29.5	21	16
HCT [%]	70	70	70	70	70	70	67	70	67.5	70	76	59
LTSP [h]	2624	2924	2758	2892	3954	3881	2912	2924	2925	2918	2933	2904
RTSP [h]	5125	4654	4487	4710	3445	3390	4651	4654	4652	4659	4648	4673
HTSP [h]	1011	1182	1115	1158	1361	1489	1191	1182	1183	1183	1179	1183

Price-based control signals, hereafter called CSP-a and CSP-b, are also determined similar to CSC-a and CSC-b, to also investigate DR measures based on the electricity spot price of each of the BZs. This means that the case study is performed for four DR signals applied to six Scandinavian BZs. In general, any form of penalty signal could be used for the control and optimization. If a proper penalty signal is chosen, a building can be controlled so that it is either energy efficient, cost efficient or CO₂ efficient. It would also be possible to select a combination of the different penalty signals for the building control [11].

4.3. Case Study Results

Figure 6 illustrates the principle of the CSC-a control during 48 h of the heating season exemplary for DK1. Figure 6a shows the CO_{2eq.} intensity and both thresholds, LCT and HCT. Figure 6b presents the measured temperatures in the DHW tank and the start and stop TSPs of the DHW hysteresis control. These TSPs vary depending on the CO_{2eq.} intensity signal. The same principle is shown for SH in Figure 6c. It is visible from Figure 6d that the electric radiators and the electric resistance heater for DHW heating are operated depending on the CO_{2eq.} intensity signal and according to the proposed temperature hysteresis.

The energy use, CO_{2eq.} emissions and costs are compared to the reference cases for each respective BZ. The relative difference in total annual emissions (Em.) for each BZ is calculated by

$$Em.(BZ_i) = \frac{Em.BZ_i,PRBC}{Em.BZ_i,BAU} * 100 - 100 [\%] \quad (10)$$

Equation (10) can also be applied to determine the relative changes for annual energy use and annual costs, respectively. Results are presented in Table 5.

In general, the energy use increases for all DR cases. Regarding CSC, annual CO_{2eq.} emissions decrease for NO2 while they remain rather close to the reference case for the other BZs. For NO3, the daily fluctuations in average CO_{2eq.} intensity are too low to benefit from DR measures. Comparing results for NO2 and NO3 regarding overall emission savings, it demonstrates that electricity imports should be properly considered as they influence significantly the variations of CO_{2eq.} intensities. These variations have shown to be important to make the CO_{2eq.}-based DR effective.

Regarding CSP, costs increase slightly for NO2 and NO3 while they decrease for SE4, DK1, and FIN. For SE4, DK1, and FIN, cost savings can be achieved as daily price fluctuations are sufficient. High daily fluctuations of prices do usually not occur in Norway and northern Sweden. Therefore, for NO2, NO3, and SE1, consuming during slightly decreased electricity spot prices is outbalanced by

an increase in total energy use. Furthermore, using price-based control, overall emissions increase significantly for NO₂, NO₃, SE1, and SE4 as a result of typically high CO_{2eq.} intensities at low-price periods (as shown Figure 3).

It is obvious, that reductions of CO_{2eq.} emissions and costs are possible, but that they are very dependent on the characteristics of the CO_{2eq.} intensity and the electricity spot price. Savings could be increased, if different thresholds (LCT and HCT) were applied, not taking NO₃ as a reference regarding the number of hours per segment. Absolute savings depend on the LCT and HCT as well as the principle used to obtain the respective control signals. In addition, the maximum absolute savings should ideally be evaluated using MPC. Therefore, here, the performance of each control should be considered relative to each other rather than in absolute terms.




Figure 6. Illustration of the control principle for DK1 case CSC-a during a 48 h period, where (a) shows the CO_{2eq.} intensity, (b) shows the DHW temperatures and hysteresis set-points, (c) shows the measured air temperature and the temperature set-point for space heating and (d) shows the power of the electric radiators and the electric auxiliary heater (DHWstart and DHWstop are the start and stop temperatures for DHW; TM is two temperature measurements in the water tank; SH TSP is space heating temperature set-point; QAux is the electric resistance heater).

Table 5. Cost and CO_{2eq.} emission savings relative to the respective reference cases for all six bidding zones (E_{Use}—energy use; Em.—emissions; CSC—control strategy carbon; CSP—control strategy price).

	CSC-a			CSC-b			CSP-a			CSP-b		
	E _{Use}	Em.	Costs	E _{Use}	Em.	Costs	E _{Use}	Em.	Costs	E _{Use}	Em.	Costs
	%	%	%	%	%	%	%	%	%	%	%	%
NO2	+9	−8	+10	+3	−1	+2	+7	+21	+2	+4	+9	+1
NO3	+9	+3	+10	+3	+2	+2	+7	+13	+2	+4	+6	+1
SE1	+9	+0	+11	+3	+1	+2	+7	+14	+1	+4	+8	+1
SE4	+9	+0	+10	+3	+1	+1	+7	+11	−3	+4	+6	−1
DK1	+10	+1	+2	+3	+2	+1	+7	+1	−6	+4	+2	−1
FIN	+9	+5	+6	+3	+2	+1	+8	+8	−9	+4	+3	−3

Table 6 presents CO_{2eq.} emission and cost savings for DHW heating and SH, separately. It can be seen that SH is the main contributor to total emission or cost savings because, for such a building with limited thermal insulation, the share of electricity use is much more significant for SH than for DHW heating. This will be different for buildings with better insulation levels. For example, regarding CSC-a in DK1, it can be seen that, even though DR measures for DHW heating lead to 12% emission savings, the overall emissions increase by 1% because the emissions resulting from SH increase by 3%.

Table 6. Cost and CO_{2eq.} emission savings separated for DHW and SH (results are given in %).

	Emissions						Costs					
	CSC-a			CSC-b			CSP-a			CSP-b		
	Total	DHW	SH	Total	DHW	SH	Total	DHW	SH	Total	DHW	SH
NO2	−8	−17	−6	−1	+17	−3	+2	−5	+3	+1	−5	+2
NO3	+3	−3	+3	+2	+14	+0	+2	−7	+3	+1	−5	+2
SE1	+0	−3	+1	+1	+20	−1	+1	−9	+2	+1	−7	+2
SE4	+0	−7	+0	+1	+16	−1	−3	−20	+1	−1	−13	+2
DK1	+1	−12	+3	+2	−1	+2	−6	−27	−1	−1	−15	+2
FIN	+5	+0	+6	+2	+6	+2	−9	−32	−3	−3	−21	+1

Furthermore, CO_{2eq.} emissions for DHW heating are decreased significantly in most of the zones using CSC-a. On the contrary, in the Norwegian and Swedish BZs, these emissions increase significantly using CSC-b. Using CSC-b, the water storage tanks are typically charged during late evenings whereas the next peak for DHW withdrawal only occurs the next morning. These peaks of DHW withdrawal happen when the CO_{2eq.} intensities of the electricity mix are rather low. In other words, CSC-b shifts the operation from low CO_{2eq.} intensities (meaning peaks of DHW withdrawal) to higher CO_{2eq.} intensities (meaning late evenings). Regarding costs, these DR strategies applied to DHW heating are very promising to decrease the operational costs. Operational costs are decreased for all BZs for both CSP-a and CSP-b considering DHW heating. In conclusion, efficient DR measures using PRBC can be implemented for the DHW heating. However, the performance of these controls are moderate for SH. The price-based controls did not manage to decrease operational costs for SH for most cases. On the one hand, this can be due to the low daily fluctuations of the electricity spot prices. On the other hand, this can be due to the low insulation level and thermal mass of the building as well as the inherent limitations of PRBC compared to MPC.

5. Conclusions

This work consists of two distinct but complementary parts. Firstly, a generic methodology is proposed to determine the hourly average CO_{2eq.} intensity of the electricity mix of a bidding zone (BZ) also considering time-varying CO_{2eq.} intensities of electricity imports. Northern Europe is taken as a case. Secondly, this case study is extended to investigate the performance of demand response

measures based on the evaluated $\text{CO}_{2\text{eq}}$ intensity. These measures aim at decreasing the environmental impact of the heating system operation of a typical Norwegian residential building.

The proposed methodology to evaluate the hourly average $\text{CO}_{2\text{eq}}$ intensity of the electricity mix is an adaptation of multi-regional input–output models (MRIO). For each electricity generation technology (EGT), the method enforces the balance between electricity generation plus imports and electricity consumption plus exports. This balance is satisfied for both EGT and BZ at each hour of the year. Regarding the CO_2 factor for a specific EGT, it is shown that they can vary significantly among references depending on their respective assumptions. Among different possible applications, the average $\text{CO}_{2\text{eq}}$ intensity that is determined using this methodology can be used as a control signal in predictive controls for building energy systems. The average $\text{CO}_{2\text{eq}}$ intensity can actually be predicted using the forecast on hourly electricity generation provided by ENTSO-E.

Firstly, the methodology is applied to Northern Europe using CO_2 factors per EGT from the Ecoinvent database. It enables to highlight some important characteristics of this power market. Especially in Norway and northern Sweden, the electricity generation is characterized by a high share of hydropower in the electricity mix. These plants are typically operated when the price for electricity is high which happens during periods of high electricity demand. Therefore, the average $\text{CO}_{2\text{eq}}$ intensities are usually low at times of high electricity demand. On the contrary, for countries where the electricity generation relies more on fossil fuels, average $\text{CO}_{2\text{eq}}$ intensities are typically high at times of high electricity demand. In this respect, it is also important to consider electricity imports and their varying $\text{CO}_{2\text{eq}}$ intensity when evaluating the average $\text{CO}_{2\text{eq}}$ intensity. As soon as Norway imports electricity from neighboring BZs (typically in periods with low electricity demands), the $\text{CO}_{2\text{eq}}$ intensity can increase significantly because electricity generation is usually more carbon-intensive in Norway's neighboring countries.

Secondly, the average $\text{CO}_{2\text{eq}}$ intensity evaluated for Northern Europe is implemented into a predictive rule-based control (PRBC) to operate the electric heating system of a typical Norwegian residential building. The demand response measures based on the average $\text{CO}_{2\text{eq}}$ intensity aim at decreasing the environmental impact of the heating system. Results prove that carbon-based controls can achieve emission reductions if daily fluctuations of the $\text{CO}_{2\text{eq}}$ intensity are large enough to counterbalance for the increased electricity use generated by load shifting. As an example, the potential for emission reductions is higher in NO_2 compared to NO_3 because the daily fluctuations in the $\text{CO}_{2\text{eq}}$ intensity in NO_2 are much larger than in NO_3 . As these fluctuations in NO_2 are mainly generated by imports, it further confirms the need to account for these imports in demand response analysis. If the heating system is controlled according to spot prices, results also confirm that price-based controls lead to increased emissions in the Scandinavian countries as operation is usually shifted towards night-time (for the case of Norway) when cheap but carbon-intensive electricity is indirectly imported from Germany, Poland, or the Netherlands (via Denmark and Sweden).

Demand response using PRBC applied to DHW heating show a strong potential for cost and emission savings. Conclusions regarding SH are more balanced. Depending on the control strategy and BZ, the PRBC manages to decrease the SH costs or the related $\text{CO}_{2\text{eq}}$ emissions. The case building was taken representative for the Norwegian building stock and it results to a relatively low-level of thermal insulation. Energy use for SH is thus dominant over DHW. Consequently, the overall performance of DR using PRBC for heating (i.e., SH and DHW) is also balanced. Conclusions regarding SH may be different for buildings with better insulation as they have a higher storage efficiency. In addition, PRBC relies on predefined control rules which may not always be optimal. It should be explored whether advanced controls, such as model-predictive control (MPC), would lead to significant improvements regarding overall cost and emission savings.

Author Contributions: Regarding the methodology to evaluate the hourly average $\text{CO}_{2\text{eq}}$ intensity, conceptualization was done by L.G. and J.C.; methodology and software were handled by C.S. and J.C.; validation, formal analysis, investigation, data curation, and visualization were the work of S.S. and J.C.; writing and original draft preparation was done by J.C. Regarding the case study on demand response using the $\text{CO}_{2\text{eq}}$

intensity as a control signal, J.C. developed the building simulation model, implemented the control, ran the simulations, analyzed the data, visualized the results, and wrote the original draft of the article. Conceptualization and methodology were done by L.G. and J.C. All authors contributed to reviewing and editing the original article. The work was supervised by L.G.

Funding: This research received no external funding.

Acknowledgments: The authors would like to acknowledge IEA EBC Annex 67 “Energy Flexible Buildings”, IEA HPT Annex 49 “Design and Integration of Heat Pumps for nZEBs” as well as the Research Centre on Zero Emission Neighbourhoods in Smart Cities (FME ZEN). Sebastian Stinner gratefully acknowledges that his contribution was supported by a research grant from E.ON Stipendienfonds im Stifterverband für die Deutsche Wissenschaft (project number T0087/29896/17).

Conflicts of Interest: The authors declare no conflict of interest.

Nomenclature

BZ	Bidding zone	LCA	Life-cycle assessment
CI	Carbon intensity	LCT	Low CO _{2eq.} intensity threshold
CSC	Control strategy carbon	MPC	Model-predictive control
CSP	Control strategy price	MRIO	Multi-regional input–output
DHW	Domestic hot water	n ₅₀	Air changes per hour at 50 Pa pressure difference
DR	Demand response	PRBC	Predictive rule-based control
EGT	Electricity generation technology	SH	Space heating
Em.	Emissions	TSO	Transmission system operator
ENTSO-E	European Network of TSOs for Electricity	TSP	Temperature set-point
HCT	High CO _{2eq.} intensity threshold	ZEB	Zero Emission Building
HDS	Heat distribution system	η _{HR}	Heat recovery effectiveness
HVAC	Heating, ventilation, and air-conditioning	max	Maximum
		min	Minimum

Appendix A




Figure A1. Daily profiles for DHW use and internal heat gains from electrical appliances, occupancy and lighting [15].

Table A1. Comparison of CO₂ factors per electricity generation technology (EGT) from different references [39].

Electricity Generation Technology (EGT)	Emission Factor [gCO _{2eq} /kWh _e]		Name of EGT in Ecoinvent (for Reproduction Purposes)	Emission Factor (gCO _{2eq} /kWh _e) Ecoinvent (Applied Here)
	IPCC	EEA		
Biomass	740	-	Electricity, high voltage {SE} heat and power co-generation, wood chips, 6667 kW, state-of-the-art 2014 Alloc Rec, U	60 ¹
Fossil brown coal/Lignite	820	-	Electricity, high voltage {DE} electricity production, lignite Alloc Rec, U	1240
Fossil coal-derived gas	-	-	Electricity, high voltage {DE} treatment of coal gas, in power plant Alloc Rec, U	1667
Fossil gas	490	-	Electricity, high voltage {DK} heat and power co-generation, natural gas, conventional power plant, 100MW electrical Alloc Rec, U	529
Fossil hard coal	1001	-	Electricity, high voltage {DK} heat and power co-generation, hard coal Alloc Rec, U	1266
Fossil oil	-	-	Electricity, high voltage {DK} heat and power co-generation, oil Alloc Rec, U	1000
Fossil oil shale	-	-	No data in Ecoinvent (assumed value)	1000
Fossil peat	-	-	Electricity, high voltage {FI} electricity production, peat Alloc Rec, U	1071
Geothermal	38	-	Electricity, high voltage {DE} electricity production, deep geothermal Alloc Rec, U	95
Hydro pumped storage	24	-	Electricity, high voltage {NO} electricity production, hydro, pumped storage Alloc Rec, U	62
Hydro run-of-river and poundage	24	-	Electricity, high voltage {SE} electricity production, hydro, run-of-river Alloc Rec, U	5
Hydro water reservoir	24	-	Electricity, high voltage {NO} electricity production, hydro, reservoir, alpine region Alloc Rec, U	8
Marine	24	-	No data in Ecoinvent (assumed value - as wind offshore)	18
Nuclear	12	-	Electricity, high voltage {SE} electricity production, nuclear, pressure water reactor Alloc Rec, U	13
Other	-	-	No data in Ecoinvent (assumed value - avg. fossil fuels)	979
Other RES	-	-	No data in Ecoinvent (assumed value - avg. RES)	46
Solar	45	-	Electricity, low voltage {DK} electricity production, photovoltaic, 3kWp slanted-roof installation, single-Si, panel, mounted Alloc Rec, U	144
Waste	-	-	Electricity, for reuse in municipal waste incineration only {DK} treatment of municipal solid waste, incineration Alloc Rec, U	500
Wind offshore	12	-	Electricity, high voltage {DK} electricity production, wind, 1-3MW turbine, offshore Alloc Rec, U	18
Wind onshore	11	-	Electricity, high voltage {DK} electricity production, wind, 1-3MW turbine, onshore Alloc Rec, U	14
Imports from all bidding zones with calculated hourly data	-	0		0
Imports from Russia	-	-	Electricity, high voltage {RU} market for Alloc Rec, U	862
Imports from Estonia	-	762	Electricity, high voltage {EE} market for Alloc Rec, U	1179
Imports from Poland	-	671	Electricity, high voltage {PL} market for Alloc Rec, U	1225
Imports from Belgium	-	212	Electricity, high voltage {BE} market for Alloc Rec, U	365
Imports from Great Britain	-	389	Electricity, high voltage {GB} market for Alloc Rec, U	762

¹ Assuming that biogenic CO₂ is climate neutral; 100-year spruce rotation assumption and dynamic GWP for climate impact of burning wood; does not consider climate impact from CO₂ from wood combustion.

References

1. Aduda, K.O.; Labeodan, T.; Zeiler, W.; Boxem, G.; Zhao, Y. Demand side flexibility: Potentials and building performance implications. *Sustain. Cities Soc.* **2016**, *22*, 146–163. [[CrossRef](#)]
2. Clauß, J.; Finck, C.; Vogler-Finck, P.; Beagon, P. Control strategies for building energy systems to unlock demand side flexibility—A review. In Proceedings of the 15th International Conference of the International Building Performance Simulation Association, San Francisco, CA, USA, 7–9 August 2017.
3. International Energy Agency (IEA). *Key World Energy Statistics*; International Energy Agency: Paris, France, 2015; Volume 82, p. 6. [[CrossRef](#)]

4. Arteconi, A.; Hewitt, N.J.; Polonara, F. State of the art of thermal storage for demand-side management. *Applied Energy* **2012**, *93*, 371–389. [[CrossRef](#)]
5. Chen, Y.; Xu, P.; Gu, J.; Schmidt, F.; Li, W. Measures to improve energy demand flexibility in buildings for demand response (DR): A review. *Energy Build.* **2018**, *177*, 125–139. [[CrossRef](#)]
6. Yin, R.; Kara, E.C.; Li, Y.; DeForest, N.; Wang, K.; Yong, T.; Stadler, M. Quantifying flexibility of commercial and residential loads for demand response using setpoint changes. *Appl. Energy* **2016**, *177*, 149–164. [[CrossRef](#)]
7. Haider, H.T.; See, O.H.; Elmenreich, W. A review of residential demand response of smart grid. *Renew. Sustain. Energy Rev.* **2016**, *59*, 166–178. [[CrossRef](#)]
8. Vandermeulen, A.; van der Heijde, B.; Helsen, L. Controlling district heating and cooling networks to unlock flexibility: A review. *Energy* **2018**, *151*, 103–115. [[CrossRef](#)]
9. Vandermeulen, A.; Vandeplas, L.; Patteeuw, D.; Sourbron, M.; Helsen, L. Flexibility offered by residential floor heating in a smart grid context: The role of heat pumps and renewable energy sources in optimization towards different objectives. In Proceedings of the 12th IEA Heat Pump Conference, Rotterdam, The Netherlands, 15–18 May 2017.
10. Lopes, R.A.; Chambel, A.; Neves, J.; Aelenei, D.; Martins, J. A literature review of methodologies used to assess the energy flexibility of buildings. *Energy Procedia* **2016**, *91*, 1053–1058. [[CrossRef](#)]
11. Junker, R.G.; Azar, A.G.; Lopes, R.A.; Lindberg, K.B.; Reynders, G.; Relan, R.; Madsen, H. Characterizing the energy flexibility of buildings and districts. *Appl. Energy* **2018**, *225*, 175–182. [[CrossRef](#)]
12. Finck, C.; Li, R.; Kramer, R.; Zeiler, W. Quantifying demand flexibility of power-to-heat and thermal energy storage in the control of building heating systems. *Appl. Energy* **2017**, *209*, 409–425. [[CrossRef](#)]
13. Péan, T.; Ortiz, J.; Salom, J. Impact of Demand-Side Management on Thermal Comfort and Energy Costs in a Residential nZEB. *Buildings* **2017**, *7*, 37. [[CrossRef](#)]
14. Lizana, J.; Friedrich, D.; Renaldi, R.; Chacartegui, R. Energy flexible building through smart demand-side management and latent heat storage. *Appl. Energy* **2018**, *230*, 471–485. [[CrossRef](#)]
15. Clauß, J.; Stinner, S.; Sartori, I.; Georges, L. Predictive rule-based control to activate the energy flexibility of Norwegian residential buildings: Case of an air-source heat pump and direct electric heating. *Appl. Energy* **2019**, *237*, 500–518. [[CrossRef](#)]
16. Fischer, D.; Bernhardt, J.; Madani, H.; Wittwer, C. Comparison of control approaches for variable speed air source heat pumps considering time variable electricity prices and PV. *Appl. Energy* **2017**, *204*, 93–105. [[CrossRef](#)]
17. Alimohammadisagvand, B.; Jokisalo, J.; Kilpeläinen, S.; Ali, M.; Sirén, K. Cost-optimal thermal energy storage system for a residential building with heat pump heating and demand response control. *Appl. Energy* **2016**, *174*, 275–287. [[CrossRef](#)]
18. Alimohammadisagvand, B.; Jokisalo, J.; Sirén, K. Comparison of four rule-based demand response control algorithms in an electrically and heat pump-heated residential building. *Appl. Energy* **2018**, *209*, 167–179. [[CrossRef](#)]
19. Le Dréau, J.; Heiselberg, P. Energy flexibility of residential buildings using short term heat storage in the thermal mass. *Energy* **2016**, *111*, 991–1002. [[CrossRef](#)]
20. Dar, U.I.; Sartori, I.; Georges, L.; Novakovic, V. Advanced control of heat pumps for improved flexibility of Net-ZEB towards the grid. *Energy Build.* **2014**, *69*, 74–84. [[CrossRef](#)]
21. Vogler-Finck, P.J.C.; Wisniewski, R.; Popovski, P. Reducing the carbon footprint of house heating through model predictive control—A simulation study in Danish conditions. *Sustain. Cities Soc.* **2018**, *42*, 558–573. [[CrossRef](#)]
22. Heidmann Pedersen, T.; Hedegaard, R.E.; Petersen, S. Space heating demand response potential of retrofitted residential apartment blocks. *Energy Build.* **2017**, *141*, 158–166. [[CrossRef](#)]
23. Hedegaard, R.E.; Pedersen, T.H.; Petersen, S. Multi-market demand response using economic model predictive control of space heating in residential buildings. *Energy Build.* **2017**, *150*, 253–261. [[CrossRef](#)]
24. Dahl Knudsen, M.; Petersen, S. Demand response potential of model predictive control of space heating based on price and carbon dioxide intensity signals. *Energy Build.* **2016**, *125*, 196–204. [[CrossRef](#)]
25. Péan, T.Q.; Salom, J.; Ortiz, J. Environmental and Economic Impact of Demand Response Strategies for Energy Flexible Buildings. *Proc. BSO* **2018**, *2018*, 277–283.

26. Patteeuw, D.; Bruninx, K.; Arteconi, A.; Delarue, E.; D'haeseleer, W.; Helsen, L. Integrated modeling of active demand response with electric heating systems coupled to thermal energy storage systems. *Appl. Energy* **2015**, *151*, 306–319. [[CrossRef](#)]
27. De Coninck, R.; Baetens, R.; Saelens, D.; Woyte, A.; Helsen, L. Rule-based demand-side management of domestic hot water production with heat pumps in zero energy neighbourhoods. *J. Build. Perform. Simul.* **2014**, *7*, 271–288. [[CrossRef](#)]
28. Killian, M.; Kozek, M. Ten questions concerning model predictive control for energy efficient buildings. *Build. Environ.* **2016**, *105*, 403–412. [[CrossRef](#)]
29. Fischer, D.; Madani, H. On heat pumps in smart grids: A review. *Renew. Sustain. Energy Rev.* **2017**, *70*, 342–357. [[CrossRef](#)]
30. IEA; Nordic Energy Research. *Nordic Energy Technology Perspectives 2016 Cities, Flexibility and Pathways to Carbon-Neutrality*; Nordic Energy Research: Oslo, Norway, 2016.
31. NordPoolGroup. NordPool 2018. Available online: <https://www.nordpoolgroup.com/message-center-container/newsroom/exchange-message-list/2018/q2/nord-pool-key-statistics--may-2018/> (accessed on 13 June 2018).
32. NordPoolGroup. NordPool-About Us 2018. Available online: <https://www.nordpoolgroup.com/About-us/> (accessed on 15 October 2018).
33. NordPoolGroup. NordPool Bidding Areas 2018. Available online: <https://www.nordpoolgroup.com/the-power-market/Bidding-areas/> (accessed on 28 April 2018).
34. Wiebe, K.S. The impact of renewable energy diffusion on European consumption-based emissions. *Econ. Syst. Res.* **2016**, *28*, 133–150. [[CrossRef](#)]
35. Pan, L.; Liu, P.; Li, Z.; Wang, Y. A dynamic input–output method for energy system modeling and analysis. *Chem. Eng. Res. Des.* **2018**, *131*, 183–192. [[CrossRef](#)]
36. Guevara, Z.; Domingos, T. The multi-factor energy input–output model. *Energy Econ.* **2017**, *61*, 261–269. [[CrossRef](#)]
37. Palmer, G. An input–output based net-energy assessment of an electricity supply industry. *Energy* **2017**, *141*, 1504–1516. [[CrossRef](#)]
38. Arteconi, A.; Patteeuw, D.; Bruninx, K.; Delarue, E.; D'haeseleer, W.; Helsen, L. Active demand response with electric heating systems: Impact of market penetration. *Appl. Energy* **2016**, *177*, 636–648. [[CrossRef](#)]
39. Clauß, J.; Stinner, S.; Solli, C.; Lindberg, K.B.; Madsen, H.; Georges, L. A generic methodology to evaluate hourly average CO₂eq. intensities of the electricity mix to deploy the energy flexibility potential of Norwegian buildings. In Proceedings of the 10th International Conference on System Simulation in Buildings, Liege, Belgium, 10–12 December 2018. In Proceedings of the 10th International Conference on System Simulation in Buildings, Liege, Belgium, 10–12 December 2018.
40. Energinet. Retningslinjer for Miljødeklarationen for el 2017, 1–16. Available online: <https://www.google.com.hk/url?sa=t&rct=j&q=&esrc=s&source=web&cd=1&cad=rja&uact=8&ved=2ahUKEwiFtdmLn8DhAhXsyIsBHUtOChwQFjAAegQIAxAC&url=https%3A%2F%2Fenerginet.dk%2F%2Fmedia%2FEnerginet%2FEI-RGD%2FRetningslinjer-for-miljdeklarationen-for-el.pdf%3Fla%3Dda&usg=AOvVaw3lFa3nFoF1MpOpXtSk5pRa> (accessed on 3 February 2019).
41. Milovanoff, A.; Dandres, T.; Gaudreault, C.; Cheriet, M.; Samson, R. Real-time environmental assessment of electricity use: A tool for sustainable demand-side management programs. *Int. J. Life Cycle Assess.* **2018**, *23*, 1981–1994. [[CrossRef](#)]
42. Roux, C.; Schalbart, P.; Peuportier, B. Accounting for temporal variation of electricity production and consumption in the LCA of an energy-efficient house. *J. Clean. Prod.* **2016**, *113*, 532–540. [[CrossRef](#)]
43. Tomorrow. CO₂-equivalent Model Explanation 2018. Available online: <https://github.com/tmrowco/electricitymap-contrib/blob/master/CO2eqModelExplanation.ipynb> (accessed on 4 May 2018).
44. Bettle, R.; Pout, C.H.; Hitchin, E.R. Interactions between electricity-saving measures and carbon emissions from power generation in England and Wales. *Energy Policy* **2006**, *34*, 3434–3446. [[CrossRef](#)]
45. Hawkes, A.D. Estimating marginal CO₂ emissions rates for national electricity systems. *Energy Policy* **2010**, *38*, 5977–5987. [[CrossRef](#)]
46. Corradi, O. Estimating the Marginal Carbon Intensity of Electricity with Machine Learning 2018. Available online: <https://medium.com/electricitymap/using-machine-learning-to-estimate-the-hourly-marginal-carbon-intensity-of-electricity-49eade43b421> (accessed on 28 February 2019).

47. Graabak, I.; Bakken, B.H.; Feilberg, N. Zero emission building and conversion factors between electricity consumption and emissions of greenhouse gases in a long term perspective. *Environ. Clim. Technol.* **2014**, *13*, 12–19. [CrossRef]
48. Askeland, M.; Jaehnert, S.; Mo, B.; Korpas, M. Demand response with shiftable volume in an equilibrium model of the power system. In Proceedings of the 2017 IEEE Manchester PowerTech, Manchester, UK, 18–22 June 2017. [CrossRef]
49. Quoilin, S.; Hidalgo Ganzalez, I.; Zucker, A. *Modelling Future EU Power Systems Under High Shares of Renewables The Dispa-SET 2.1 Open-Source Model*; Publications Office of the European Union: Luxembourg, LUXEMBOURG, 2017. [CrossRef]
50. Tomorrow. Electricity Map Europe 2016. Available online: <https://www.electricitymap.org/?wind=false&solar=false&page=country&countryCode=NO> (accessed on 13 April 2018).
51. Tranberg, B. Cost Allocation and Risk Management in Renewable Electricity Networks. PhD Dissertation, Department of Engineering, Aarhus University, Danske Commodities, Aarhus, Denmark, 2019.
52. IPCC. *Climate Change 2014: Mitigation of Climate Change. Contribution of Working Group III to the Fifth Assessment Report of the Intergovernmental Panel on Climate Change*; Edenhofer, O., Pichs-Madruga, R., Sokona, Y., Farahani, E., Kadner, S., Seyboth, K., Adler, A., Baum, I., Brunner, S., Eickemeier, P., et al., Eds.; Cambridge University Press: Cambridge, UK; New York, NY, USA, 2014.
53. Schlömer, S.; Bruckner, T.; Fulton, L.; Hertwich, E.; McKinnon, A.; Perczyk, D.; Roy, J.; Schaeffer, R.; Sims, R.; Smith, P.; et al. Annex III: Technology-specific cost and performance parameters. In *Climate Change 2014: Mitigation of Climate Change. Contribution of Working Group III to the Fifth Assessment Report of the Intergovernmental Panel on Climate Change*; Edenhofer, O., Pichs-Madruga, R., Sokona, Y., Farahani, E., Kadner, S., Seyboth, K., Adler, A., Baum, I., Brunner, S., Eickemeier, P., et al., Eds.; Cambridge University Press: Cambridge, UK; New York, NY, USA, 2014.
54. Ecoinvent. 2016. Available online: www.ecoinvent.org (accessed on 9 April 2018).
55. EEA. Overview of Electricity Production and Use in Europe 2018. Available online: <https://www.eea.europa.eu/data-and-maps/indicators/overview-of-the-electricity-production-2/assessment> (accessed on 12 April 2018).
56. Bachmann, C.; Roorda, M.J.; Kennedy, C. Developing a multi-scale multi-region input–output model developing a multi-scale multi-region input–output model. *Econ. Syst. Res.* **2015**, *27*, 172–193. [CrossRef]
57. Kristjansdottir, T.F.; Houlihan-Wiberg, A.; Andresen, I.; Georges, L.; Heeren, N.; Good, C.S.; Brattebø, H. Is a net life cycle balance for energy and materials achievable for a zero emission single-family building in Norway? *Energy Build.* **2018**, *168*, 457–469. [CrossRef]
58. Brattebø, H.; O’Born, R.; Sartori, I.; Klinski, M.; Nørstebø, B. Typologier for Norske Boligbygg—Eksempler på Tiltak for Energieffektivisering. Available online: <https://brage.bibsys.no/xmlui/handle/11250/2456621> (accessed on 3 February 2019).
59. Goia, F.; Finocchiaro, L.; Gustavsen, A. Passivhus Norden|Sustainable Cities and Buildings The ZEB Living Laboratory at the Norwegian University of Science and Technology: A Zero Emission House for Engineering and Social science Experiments. In Proceedings of the 7th Nordic Passive House Conference, Copenhagen, Denmark, 20–21 August 2015.
60. Halvgaard, R.; Poulsen, N.; Madsen, H.; Jørgensen, J. Economic model predictive control for building climate control in a smart grid. In Proceedings of the 2012 IEEE PES Innovative Smart Grid Technologies (ISGT), Washington, DC, USA, 16–20 January 2012; pp. 1–6. [CrossRef]
61. Madsen, H.; Parvizi, J.; Halvgaard, R.; Sokoler, L.E.; Jørgensen, J.B.; Hansen, L.H.; Hilger, K.B. Control of Electricity Loads in Future Electric Energy Systems. In *Handbook of Clean Energy Systems*; Wiley: Hoboken, NJ, USA, 2015.
62. Johnsen, T.; Taksdal, K.; Clauß, J.; Georges, L. Influence of thermal zoning and electric radiator control on the energy flexibility potential of Norwegian detached houses. In Proceedings of the CLIMA 2019, Bucharest, Romania, 26–29 May 2019.
63. EQUA. EQUA Simulation AB 2015. Available online: <http://www.equa.se/en/ida-ice> (accessed on 16 October 2015).
64. EQUA Simulation AB; EQUA Simulation Finland Oy. *Validation of IDA Indoor Climate and Energy 4.0 with Respect to CEN Standards EN 15255-2007 and EN 15265-2007*; EQUA Simulation Technology Group: Solna, Sweden, 2010.

65. EQUA Simulation AB. *Validation of IDA Indoor Climate and Energy 4.0 build 4 with Respect to ANSI/ASHRAE Standard 140-2004*; EQUA Simulation Technology Group: Solna, Sweden, 2010.
66. Achermann, M.; Zweifel, G. *RADTEST—Radiant Heating and Cooling Test Cases Supporting Documents*; HTA Luzern: Luzern, Switzerland, 2003.
67. Bring, A.; Sahlin, P.; Vuolle, M. *Models for Building Indoor Climate and Energy Simulation Models for Building Indoor Climate and Energy Simulation 1. Executive Background and Summary*; Department of Building Sciences, KTH: Stockholm, Sweden, 1999.
68. Sahlin, P. *Modelling and Simulation Methods for Modular Continuous Systems in Buildings*; Royal Institute of Technology: Stockholm, Sweden, 1996.
69. Kipping, A.; Trømborg, E. Hourly electricity consumption in Norwegian households—Assessing the impacts of different heating systems. *Energy* **2015**, *93*, 655–671. [[CrossRef](#)]
70. Fischer, D.; Lindberg, K.B.; Madani, H.; Wittwer, C. Impact of PV and variable prices on optimal system sizing for heat pumps and thermal storage. *Energy Build.* **2017**, *128*, 723–733. [[CrossRef](#)]
71. SN/TS3031:2016. *Bygningers Energiytelse, Beregning av Energibehov og Energiforsyning*; Standard Norge: Oslo, Norway, 2016.
72. Ahmed, K.; Akhondzada, A.; Kurnitski, J.; Olesen, B. Occupancy schedules for energy simulation in new prEN16798-1 and ISO/FDIS 17772-1 standards. *Sustain. Cities Soc.* **2017**, *35*, 134–144. [[CrossRef](#)]
73. ISO17772-1. *Energy Performance of Buildings—Indoor Environmental Quality—Part1: Indoor Environmental Input Parameters for the Design and Assessment of Energy Performance of Buildings*; International Organization for Standardization: Geneva, Switzerland, 2017.
74. OpenStreetMap. Shiny Weather Data 2017. Available online: <https://rokka.shinyapps.io/shinyweatherdata/> (accessed on 20 May 2017).
75. NordPoolGroup. NordPool Historical Market Data. Available online: <https://www.nordpoolgroup.com/historical-market-data/> (accessed on 16 April 2018).
76. Standard Norge. *NS-EN 15251:2007 Indoor Environmental Input Parameters for Design and Assessment of Energy Performance of Buildings Addressing Indoor Air Quality, Thermal Environment, Lighting and Acoustics*; Standard Norge: Oslo, Norway, 2007.



© 2019 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<http://creativecommons.org/licenses/by/4.0/>).