

Supplementary Materials

Shear Thickening Fluid and Sponge-Hybrid Triboelectric Nanogenerator for Motion Sensor Array Based Lying State Detection System

Youngsu Kim ¹, Inkyum Kim ¹, Maesoon Im ^{2,3,4,*} and Daewon Kim ^{5,6,*}

¹ Department of Electronics and Information Convergence Engineering, Institute for Wearable Convergence Electronics, Kyung Hee University, 1732 Deogyong-daero, Giheung-gu, Yongin 17104, Republic of Korea

² Brain Science Institute, Korea Institute of Science and Technology (KIST), Seoul, 02792, Republic of Korea

³ Division of Bio-Medical Science and Technology, KIST School, University of Science and Technology (UST), Seoul, 02792, Republic of Korea

⁴ KHU-KIST Department of Converging Science and Technology, Kyung Hee University, Seoul, 02447, Republic of Korea

⁵ Department of Electronic Engineering, Institute for Wearable Convergence Electronics, Kyung Hee University, 1732 Deogyong-daero, Giheung-gu, Yongin 17104, Republic of Korea

⁶ Center for BrainTechnology, Korea Institute of Science and Technology, 5, Hwarang-ro 14-gil, Seongbuk-gu, Seoul 02792, Republic of Korea

* Correspondence: daewon@khu.ac.kr (D.K.) and maesoon.im@kist.re.kr (M.I.)

Table of contents

- 1. Output voltage signals with varying numbers of PET layers**
- 2. Durability performance of output current after 2 months**
- 3. Video demonstrating single channel output detection**
- 4. Video demonstrating multi-channel motion detection**

1. Output voltage signals with varying numbers of PET layers




Figure S1. Output voltage signals with changing the numbers of PET: (a) 0, (b) 2, (c) 4 with 8S, (d) 6, (e) 8, and (f) 4 with 4S.

2. Durability performance of output current after 2 months




Figure S2. Output current signals comparing the initial data and the data attained after 2 months.

3. Video demonstrating single channel output detection

Video S1. Demonstration of single channel output detection using the HTMS array.

4. Video demonstrating multi-channel motion detection

Video S2. Demonstration of multi-channel output detection using the HTMS array.