

Article

Toward a Renewable and Sustainable Energy Pattern in Non-Interconnected Rural Monasteries: A Case Study for the Xenofontos Monastery, Mount Athos

Dimitris A.I. Katsaprakakis 

Power Plant Synthesis Laboratory, Department of Mechanical Engineering, Hellenic Mediterranean University, 71410 Heraklion, Greece; dkatsap@hmu.gr; Tel.: +30-2810-379220

Abstract: The scope of this article is to study and propose optimized electricity production plants powered by renewable energy sources, in the frame of energy transition in non-interconnected, rural monasteries. Energy transition, namely, the transition from fossil fuels to renewables and rational use of energy, constitutes a major component of sustainability. In particular, monasteries constitute a special and unique category of rural communities, given their size and the scale of the electricity demand. As a case study, this work focuses on the Xenofontos Monastery, in Mount Athos. Mount Athos, practically a mountainous peninsula at the North Aegean Sea (central-south Macedonia, Greece), is an independent and self-governed community of 20 different monasteries, with no electrical interconnection between them. The electrification of these monasteries started in the 1980s, with the installation of autonomous small diesel generators. Since 2010, an attempt has been initiated to replace these generators with power production and storage technologies based on renewable energy sources, aiming to approach a more energy-independent and sustainable pattern in the peninsula. The article examines two alternative systems, with small wind turbines and photovoltaic panels as the power production units and small pumped hydro storage or electrochemical batteries as storage technologies. New operation algorithms were developed and the sizing of the systems was accomplished through the computational simulation of the examined plants' annual operations, aiming at full coverage of the power demand. The article proves that 100% power demand coverage from hydro power plants is possible with the support of pumped storage, achieving a Levelized Cost Of Electricity in the range of 0.22 EUR/kWh. This feature can be reduced at 0.11 EUR/kWh with the support of lithium-ion batteries, yet with annual power demand coverage at 90%.

Keywords: monasteries energy autonomy; hybrid power plants; pumped hydro storage; lithium-ion batteries; energy transition sustainability



Citation: Katsaprakakis, D.A. Toward a Renewable and Sustainable Energy Pattern in Non-Interconnected Rural Monasteries: A Case Study for the Xenofontos Monastery, Mount Athos. *Sustainability* **2024**, *16*, 2111. <https://doi.org/10.3390/su16052111>

Academic Editor: Nicu Bizon

Received: 4 February 2024

Revised: 25 February 2024

Accepted: 1 March 2024

Published: 3 March 2024



Copyright: © 2024 by the author. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<https://creativecommons.org/licenses/by/4.0/>).

1. Introduction

The sustainable energy autonomy of small and rural communities, located far away from the nearest electrical grid and, therefore, unlikely to be interconnected, due to the high interconnection cost and the low electricity demand, imposing no economic feasibility of the overall endeavor, constitutes traditionally a popular and favorite topic of the relevant scientific and technical community. Aiming, apart from energy autonomy, at the sustainability of the power production plants, the proposed solutions are configured with the combined operation of power production technologies from Renewable Energy Sources (RES) and energy storage technologies, formulating the so-called “Hybrid Power Plants” (HPP) [1,2].

Essentially, the energy autonomy of these small and rural communities has to face three major objectives:

- Full real-time coverage of the power demand, without external support;
- Stability and dynamic security of the power supply;

- Cost-effective production and maintenance process.

Working mainly on the aforementioned three objectives, several relevant articles can be found in the scientific literature. The most commonly met approach is the combination of wind parks or small wind turbines with photovoltaics and electrochemical batteries, to undertake the power demand of a small community [3–5]. These systems are, in general, characterized by high flexibility and modularity, due to the easily adapted size of the storage plant. Also, since the power and frequency regulation is based on power electronics, they ensure a high response rate and capacity to efficiently undertake any potential disturbances or contingencies in the power production system and the electrical grid. Finally, they exhibit low budgets. On the other hand, the setup levelized cost is considerably high, due to the batteries' high procurement levelized cost (for lithium-ion batteries in the range of 400 USD/kWh of storage capacity). This, in turn, restricts the installed storage capacity of the plant, which leads to short time periods of autonomous operation and low energy supply security. As a final result, the achievement of 100% coverage of the energy demand is very difficult with the support of electrochemical storage, precisely due to the low available storage capacity [6,7]. Recent studies have examined the capacity of such plants to operate under liberalized wholesale electricity markets, showing that a considerable drop in battery procurement costs should be achieved [3].

The drawback of the low storage capacity is often compensated with the introduction of additional alternative storage technologies, as supplements in the hybrid power plant's layout. A typical case can be the introduction of a hydrogen production and storage plant, typically with electrolysis units [4,5,8,9], approaching, in this way, "green hydrogen" production. This approach can strengthen the economic and technical features of the plant, especially when the energy demand coverage in the transportation sector is examined, although the hydrogen production still exhibits high energy costs.

Another promising amendment, with regard to the classic wind–photovoltaic–battery configuration, is the introduction of a power production technology from biomass resources, such as solid biomass, biogas, or bio-methane [1,5,10–12]. Such technologies, of course, are feasible in geographical regions rich in biomass resources, such as Egypt [11] or Cameroon [12] or the tropical climates in eastern Asia, and originate, most commonly, either from agriculture, livestock, or urban processes. The great asset that a biomass technology brings is guaranteed power production. Practically, the need to maintain thermal generators powered by fossil fuels as back-up units is eliminated, since this secure and guaranteed production is, by all means, undertaken by the biomass generators. The feasibility and the effectiveness of such systems is maximized when they are concurrently utilized for heat production, namely, as cogeneration plants. The heat can be supplied either for decentralized final usage in agricultural [13] or the urban sector [14] or through district heating networks for the heat demand coverage of a whole settlement, a neighborhood, or a community [15–17]. In most cases, especially when there are considerable heating loads during the whole annual period, the economic feasibility of these systems is high, with the payback period of the corresponding investments in the range of 4–5 years [16]. Additionally, these systems create new occupation opportunities and are characterized, in general, with high added value [17].

Approaching larger power demand scales, while the potential power production technologies remain the same, the most popular and technically feasible storage technologies are based on mechanical storage, either in the form of static pressure or in the form of gravitational energy. More specifically, energy storage with the aforementioned two alternatives is achieved with well-known Compressed Air Energy Storage systems (CAES) [18–20] and Pumped Hydro Storage systems (PHS) [21–23].

PHS systems, in general, constitute the most technically feasible and economically competitive technology, with the most installations worldwide, compared to any other available energy storage technology. They offer large storage capacities, which can provide autonomous operation periods of several days, imposing, thus, high energy supply security, a crucial parameter especially for non-interconnected electrical grids. On the condition

of available favorable land morphology, they can also exhibit a very low levelized setup cost, which can be as low as 30 EUR/kWh of storage capacity [24,25]. PHS systems have been widely studied and proposed for 100% full coverage of power demand in insular systems, offering security of supply and competitive production cost, even lower than 0.12 EUR/kWh [26–29]. The main drawbacks of PHS systems are their high budget, the requirement for specific favorable land morphology for adequate and cost-effective installation, and that they seem to be feasible for power demand higher than a minimum size (at the range of 5 MW). Additionally, they are not modular and flexible, such as the electrochemical storage devices.

In cases of no availability of favorable land morphology, such as in flat land terrains, or of low power demand, the alternative option of CAES can be introduced. The total efficiency of the storage cycle in CAES systems is in the range of 50% [30,31], while in PHS it can reach 70% [32,33]. This drawback is anticipated to be handled with the technology of adiabatic CAES, which, however, still faces major practical and technical issues regarding heat storage [34,35]. CAES are more flexible, they can be developed in small size (micro-CAES), and they do not require any specific land configurations. Micro-CAES can be a competitive option for small power demand scales [18] or for specific remote power production, such as non-interconnected desalination plants [20]. In these cases, micro-CAES can exhibit better economic features than electrochemical storage plants. On the other hand, it is not easy to develop CAES systems in the size of PHS systems, because of the required large storage capacities (in the range of hundreds of thousands of cubic meters) and at high pressures (which can be up to 70 bars). The only two so far implemented and operating CAES systems of a large size in Germany and in the USA utilize underground former salt mining caves as air storage tanks [36].

The aforementioned plants and systems have been proposed and studied for a variety of applications, such as rural settlements [5,15,37], non-interconnected islands [25,26,28,29,36], decentralized consumptions, like desalination plants [20,38], agricultural uses [13,39], etc. Following these efforts, the present article investigates the optimum solution for the power demand coverage in a rural and non-interconnected Monastery from renewable energy production and storage technologies. No similar work was found in the relevant literature. The innovation of this work lies in the peculiarities met in monasteries, regarding both the energy demand, the available resources, and the restrictions regarding the conservation of the natural environment and their historical and architectural attitude. Additionally, new operation algorithms are proposed in this article for the alternatively examined layouts. Through an iterative optimization process, new results and insights are found. As a case study, the Greek Orthodox Monastery of Xenofontos, in Mount Athos, was selected.

2. Methodology and Data

This article alternatively examines two different syntheses of hybrid power plants for the coverage of small size, rural, and non-interconnected power demand. These two alternative layouts are as follows:

- A hybrid power plant consisting of small wind turbines and a photovoltaic station, as the main power production units, a small PHS plant, as the storage unit, and a conventional diesel generator, as the back-up unit;
- A hybrid power plant consisting of small wind turbines and a photovoltaic station, as the main power production units, lithium-ion batteries, as the storage unit, and a conventional diesel generator, as the back-up unit.

As it is conceivable, the only difference regarding the involved technologies between the two examined systems is the storage technology, which, in the first case, is a small-size PHS plant and, in the second case, is a cluster of lithium-ion batteries. However, as will be seen, this unique difference introduces considerable changes in the operation and the achieved results of the HPP.

Two different operation algorithms are developed for the two alternatively examined HPPs, imposed, practically, by the technical specifications and the economic features of

the involved storage technology in each case: demand response, storage capacity, setup, and operation cost. The annual operation of each plant is computationally simulated, and according to the developed operation, algorithms and iterative executions are implemented for different sizing scenarios, aiming at the approach or even the achievement of real-time 100% coverage of the electricity demand through the whole annual period.

A fundamental economic analysis is implemented for both systems, which enables the calculation of some essential economic features, such as the setup cost, the maintenance cost, and the Levelized Cost Of Electricity (LCOE), which is also used as the sizing optimization criterion.

As a case study, as mentioned also in the previous section, the HPPs will be examined for the Monastery of Xenofontos, in Mount Athos. The annual power demand time series was developed given the power demand data captured from the existing power production and management system.

Additionally, the available RES potential was estimated from the available climate data in the European Centre for Medium-Range Weather Forecasts (ECMWF) and for the period 2000–2019 [40] for a geographical point only 5.0 km away from the geographical location of the Monastery. All meteorological data were downloaded in the form of annual time series with hourly average values. These are used for all accomplished computational simulations and calculations.

As none of these plants have so far been implemented, the whole work is purely based on the computational simulation results and not on experimental or real operation data.

3. Power Demand and Meteorological Data

3.1. Power Demand

The Monastery is powered mainly by a diesel generator set, of 200 kW nominal power output, supported by a small photovoltaic plant of 150 kW and lead-acid batteries with total storage capacity of 50 kWh. Due to the installation of these technologies, an essential power production and storage management system has also been installed, through which typical power demand daily profiles are available, however only in graphical format and not in the form of a time series. Based on the available power demand daily profiles, the annual power demand time series of hourly average values was developed. Initially, power demand daily graphical profiles for every 15 days were digitized (in total, 24 for the annual period) so as to formulate the corresponding daily power demand time series, with hourly average values. The daily profiles were introduced in the correct time positions in a new annual time series power demand with hourly average values. The gaps between the introduced daily profiles were filled with new daily profiles, produced arithmetically, following a linear interpolation with weighted factors between two consecutive available digitized profiles, so as to ensure a smooth transition between them. Finally, given that the power demand exhibits a different profile on Sundays, additional Sunday daily profiles were digitized according to the captured data, and they were introduced for every 7 days in the developed annual power demand time series. In this way, the annual power demand time series with hourly average values presented in Figure 1 was developed.

A monthly analysis of the annual power demand is given in Table 1. The average daily consumption was calculated for every month by simply dividing the total electricity consumption per month by the number of each month's days.

Table 1. Monthly analysis of the annual power demand in the Monastery of Xenofontos.

Month	Electricity Consumption (kWh)	Average Daily Consumption (kWh)	Maximum Power Demand (kW)	Minimum Power Demand (kW)
January	31,781	1025	158.6	9.4
February	27,862	995	158.6	10.1
March	33,630	1085	145.4	9.0

Table 1. Cont.

Month	Electricity Consumption (kWh)	Average Daily Consumption (kWh)	Maximum Power Demand (kW)	Minimum Power Demand (kW)
April	40,025	1334	198.4	8.2
May	37,943	1224	183.5	9.9
June	36,961	1232	161.5	10.8
July	43,976	1419	161.7	13.0
August	42,712	1378	165.1	8.5
September	35,524	1184	145.8	8.6
October	36,834	1188	158.2	6.0
November	30,376	1013	146.4	7.5
December	36,025	1162	134.0	8.3
Annual sum/minimum, maximum, and average values	433,649	1188	198.4	6.0




Figure 1. The annual power demand time series for the Monastery of Xenofontos in Mount Athos.

3.2. Meteorological Data

The available RES potential in the Monastery of Athos was estimated based on the climate conditions in the under-consideration geographical area. To this end, the available meteorological data were used from the ECMWF and for the period 2000–2019 [40] for a geographical point only 5.0 km to the northeast of the Monastery. All meteorological data were downloaded in the form of annual time series with hourly average values.

More specifically, in Figure 2, the annual fluctuation of the ambient temperature is presented for the year 2019. This ambient temperature annual time series will be used for the calculation of the electrical power output from the photovoltaic plant.

Similarly, in Figure 3, the annual fluctuation of the incident solar irradiance on the horizontal plane and the daily cumulative solar radiation are also presented. This time series will also be used for the calculation of the electrical power output from the photovoltaic plant.

Additionally, in Figure 4, the fluctuation through the 20-year measurement period of the annual maximum solar incident irradiance and the annual cumulative incident solar radiation on the horizontal plane is also presented. The minimum and the maximum annual cumulative incident solar radiation on the horizontal plane are calculated equal to 1499 kWh/m² and 1592 kWh/m² for the years 2002 and 2007, respectively.




Figure 2. Ambient temperature fluctuation for 2019 at the measurement location of the meteorological data.




Figure 3. Annual fluctuation for 2019 of the hourly average incident solar irradiance and the daily cumulative solar radiation on the horizontal plane.




Figure 4. Fluctuation through the 20-year measurement period of the annual maximum solar incident irradiance and the annual cumulative incident solar radiation on horizontal plane.

Finally, in Figure 5, the fluctuation of the wind velocity at 10 m height above ground is presented for the two consecutive years 2018 and 2019. The replication of the annual wind velocity profile is clear in this graph. The wind velocity annual time series for the year 2019 will be used for the calculation of the power production from the wind turbines. The annual average wind velocity for the 20-year measurement period is calculated equal to 4.2 m/s (minimum value) in 2000 to 4.9 m/s (maximum value) in 2012. In 2019, it was calculated at 4.5 m/s, close to the 20-year average value, which is 4.6 m/s.




Figure 5. Wind velocity fluctuation for 2018 and 2019 at 10 m height above ground at the geographical location of the meteorological data measurements.

Additionally, in Figure 6, the wind velocity annual wind rose graph, and the corresponding Weibull probability density graph is also given [41]. The wind rose graph shows a wind blowing prevailing direction from the northeast. Both graphs are given for the year 2019. The Weibull C and k parameters are calculated equal to 4.9 m/s and 1.39, respectively.




Figure 6. The (a) annual wind velocity rose graph and (b) Weibull distribution density at 10 m height above ground at the geographical location of the meteorological data measurements.

Finally, in Figure 7, the wind potential map at the under-consideration geographical area is depicted versus the annual average wind potential.




Figure 7. Wind potential map, versus the annual average wind velocity at 10 m height above ground at the geographical location.

The map was developed with the widely acknowledged application of WAsP of the Denmark Technical University [42]. To this end, the land terrain at the specific area was digitized and introduced in the application, together with the annual wind potential measurements. In the same figure, the location of the meteorological measurements station and the selected site for the wind turbine installations are also depicted, showing their vicinity (distance approximately close to 4.5 km).

4. Layouts and Operation Algorithms

The operation algorithms for the two alternative hybrid power plants are presented in this section. Both algorithms are executed for every time calculation step, namely, for every hour, given that the introduced annual time series are formulated with hourly average values.

4.1. The Hybrid Power Plant with the PHS System

The layout of the first examined system is depicted in Figure 8. It consists of small wind turbines, a photovoltaic plant, and a PHS system as a storage plant. It will be also supported by a conventional diesel generator as the back-up unit. An Energy Management System (EMS) will undertake the implementation of the operation algorithm as presented below:




Figure 8. Layout of the first examined hybrid power plant.

The operation algorithm of this HPP is analyzed in the following steps:

1. For every time calculation step j , the total power production P_w and P_{pv} from the wind turbines and the photovoltaic plant is introduced, as well as the power demand P_d . The total power production from the RES technologies P_{RES} will be

$$P_{RES} = P_w + P_{pv}, \quad (1)$$

2. For security reasons, the wind power production is always supplied for power storage, namely, it cannot be used for direct power demand coverage. The total direct penetration P_{RESp} from the photovoltaic plant is restricted at 50% of the current power demand, for dynamic security and stability reasons. In general, this percentage has been found to be from 30% to 50% for secure RES penetration in electrical systems [43–45]. In this case, given the fast response of hydro turbines, the percentage of 50% was selected. This means that

$$\text{if } P_{pv} > 0.50 \cdot P_d, \text{ then } P_{RESp} = 0.50 \cdot P_d, \quad (2)$$

$$\text{if } P_{pv} \leq 0.50 \cdot P_d, \text{ then } P_{RESp} = P_{pv}, \quad (3)$$

3. The remaining power demand P_{drem} , after the photovoltaic power penetration, will be equal to

$$P_{drem} = P_d - P_{RESp}, \quad (4)$$

4. The available power for storage P_{RESav} is equal to

$$P_{RESav} = P_w + (P_{pv} - P_{RESp}), \quad (5)$$

5. The required water volume V_p that must be pumped in the PHS upper reservoir in order to store the available power P_{RESav} for the duration t of the time calculation step is given by the following relationship (γ the specific weight of water, H_p the total pump head and η_p the average, overall pumps' efficiency):

$$V_p = P_{RESav} \cdot t \cdot \eta_p / \gamma \cdot H_p, \quad (6)$$

6. The required water volume V_T that must be removed from the PHS upper reservoir is calculated, so that the remaining power demand P_{drem} can be covered by the hydro turbines for the duration t of the time calculation step (H_h the total water falling head and η_h hydro turbines' average, overall efficiency):

$$V_h = P_{drem} \cdot t / \eta_h \cdot \gamma \cdot H_h, \quad (7)$$

7. The remaining water volume in the PHS upper reservoir at the end of the time step j will be

$$V_{st}(j) = V_{st}(j - 1) + V_p - V_h, \quad (8)$$

8. The remaining water volume $V_{st}(j)$ is checked whether it exceeds or not the maximum volume storage capacity V_{max} of the upper reservoir, and the following cases are distinguished:

- a. If $V_{st}(j) > V_{max}$, then the available power for storage P_{RESav} from the RES units cannot be fully stored. The absorbed power P_{st} for storage will be defined by the available margin for water storage in the upper reservoir, namely:

$$P_{st} = \rho \cdot g \cdot H_p \cdot [V_{max} - V_h - V_{st}(j - 1)] / (\eta_p \cdot t), \quad (9)$$

The produced power surplus P_{sur} from the RES units will be

$$P_{sur} = P_{RESav} - P_{st}, \quad (10)$$

Given the fact that the upper reservoir is full, the water volume in the reservoir will be adequate for the full coverage of the remaining power demand P_{drem} from the hydro turbines. Hence, the hydro turbines' produced power will be

$$P_h = P_d - P_{RESp}, \quad (11)$$

The power production P_{dg} from the diesel generator will be equal to zero:

$$P_{dg} = 0, \quad (12)$$

The remaining water volume in the PHS upper reservoir at the end of the current time calculation step will obviously be equal to V_{max} :

$$V_{st}(j) = V_{max}, \quad (13)$$

- b. If $V_{st}(j) \leq V_{max}$, then the available power for storage P_{RESav} from the RES units will be fully stored. The absorbed power P_{st} for storage will be equal to

$$P_{st} = P_{RESav}, \quad (14)$$

The produced power surplus P_{sur} from the RES units will be equal to zero:

$$P_{sur} = 0, \quad (15)$$

A new check is executed in order to examine whether the remaining volume $V_{st}(j)$ is lower than the minimum possibly contained volume V_{min} in the upper reservoir. The minimum contained volume V_{min} is configured mainly from the height from the reservoir's bottom of the water intake in the pipelines. The following sub-cases are distinguished:

- i. If $V_{st}(j) < V_{min}$, then the contained water volume $V_{st}(j - 1)$ in the upper reservoir is not adequate, and the remaining power demand P_{drem} cannot be fully covered by the hydro turbines. The hydro turbines' power production P_h will be defined by the contained water volume in the upper reservoir, namely:

$$P_h = \eta_h \cdot \rho \cdot g \cdot H_h \cdot [V_{st}(j - 1) + V_p - V_{min}] / t, \quad (16)$$

The power production P_{dg} from the back-up unit (the diesel generator) will be

$$P_{dg} = P_{drem} - P_h, \quad (17)$$

The remaining water volume in the PHS upper reservoir at the end of the current time calculation step will obviously be equal to V_{min} :

$$V_{st(j)} = V_{min}, \quad (18)$$

- ii. If $V_{min} \leq V_{st(j)} \leq V_{max}$, then both the remaining power demand P_{drem} can be fully covered by the hydro turbines and the available power from the RES units P_{RESav} can be fully stored. The hydro turbines' power production P_h will be given by the relationship 11 and the power storage P_{sur} will be given by the relationship 14. The power production surplus from the RES units will be zero (relationship 15). The power production from the diesel generator will be also equal to zero (relationship 12). The remaining water volume in the PHS upper reservoir will be given by the relationship 8.

4.2. The Hybrid Power Plant with the Lithium-Ion Batteries

The layout of the second examined system is depicted in Figure 9. It consists of small wind turbines, a photovoltaic plant, and a cluster of lithium-ion batteries (Li-ion) as a storage plant. It will be also supported by a diesel generator as the back-up unit. The operation of the system will be accomplished by the inverter's control system and the operation controller of the diesel generator.




Figure 9. Layout of the second examined hybrid power plant.

The operation algorithm of this second examined plant is analyzed in the following steps:

1. For every time calculation step j , the total power production P_w and P_{pv} from the wind turbines and the photovoltaic plant is introduced, as well as the power demand P_d . The total power production from the RES technologies P_{RES} will be

$$P_{RES} = P_w + P_{pv}, \quad (19)$$

2. The photovoltaic power penetration can reach 100% of the current power demand, due to the smoother power production profile, with regard to the wind turbines, and the system's management from the inverters' power electronics, which enable direct reaction to any potential disturbance in the production system. Hence, as a first step, the photovoltaic power production P_{pv} is compared to the power demand P_d :

- a. If $P_{pv} < P_d$, then all the available power production from the photovoltaic plant is supplied for the power demand coverage. The photovoltaic power direct penetration P_{pv-p} will be equal to

$$P_{pv-p} = P_{pv}, \quad (20)$$

Unlike the photovoltaic plant, the wind turbines' direct penetration is restricted up to a maximum penetration percentage with regard to the current power demand, which is defined at 50% in this study. The wind power production P_w is compared to the remaining power demand, after the photovoltaics' penetration:

- i. If $P_w < 0.50 \cdot (P_d - P_{pv-p})$, then all the available wind power production can be fully absorbed for direct power demand coverage; hence, the wind power direct penetration P_{wp} will be

$$P_{wp} = P_w, \quad (21)$$

- ii. If $P_w \geq 0.50 \cdot (P_d - P_{pv-p})$, the available wind power production exceeds the margin for direct wind power penetration, so the wind power penetration will be restricted according to the maximum allowed percentage:

$$P_{wp} = 0.50 \cdot (P_d - P_{pv-p}), \quad (22)$$

In any one of the previous two sub-cases:

- The total direct penetration of the RES units will be

$$P_{RESp} = P_{pv-p} + P_{wp}, \quad (23)$$

- The available power for storage will be

$$P_{RESav} = P_{RES} - P_{RESp}, \quad (24)$$

- The remaining power demand, after the RES units' direct penetration, will be

$$P_{drem} = P_d - P_{RESp}, \quad (25)$$

- b. If $P_{pv} \geq P_d$, then all the current power demand can be fully covered by the photovoltaic production. The direct photovoltaic penetration will be

$$P_{pv-d} = P_d, \quad (26)$$

Also,

- The direct wind power penetration will be null:

$$P_{wp} = 0, \quad (27)$$

- The total RES units' penetration will be

$$P_{RESp} = P_{pv-p}, \quad (28)$$

- The available power for storage will be given again by the relationship 24;

- The remaining power demand, after the RES units' direct penetration, will be equal to 0:

$$P_{drem} = 0. \quad (29)$$

3. Assuming that the remaining power demand P_{drem} will be fully covered by the storage plant and the available power for storage P_{RESav} will be fully stored, the new storage energy $E_{st}(j)$ in the batteries at the end of the current time calculation step with duration t will be

$$E_{st}(j) = E_{st}(j - 1) + P_{RESav} \cdot t \cdot \eta_{st} - P_{drem} \cdot t / \eta_{dis}, \quad (30)$$

where

$E_{st}(j - 1)$: the energy stored in the batteries at the end of the previous time step $j - 1$;

t : the duration of the time calculation step (1 h);

η_{st} : the charging efficiency of the batteries;

η_{dis} : the discharging efficiency of the batteries.

4. The following cases are distinguished:

- a. If $E_{st}(j) > E_{st-max}$, where E_{st-max} is the maximum total storage capacity of the batteries, then the available storage margin in the batteries is not enough for the full storage of the available power P_{RESav} . In that case, the stored power P_{st} will be defined by the available storage margin, namely, it will be

$$P_{st} = [E_{st-max} - E_{st}(j - 1) - P_{drem} \cdot t] / (t \cdot \eta_{st}), \quad (31)$$

The RES power production surplus P_{RESsur} will be

$$P_{RESsur} = P_{RESav} - P_{st}, \quad (32)$$

Obviously, due to the batteries' full storage level, the remaining power demand will be fully covered by them; hence, the batteries' power production P_{bat} will be

$$P_{bat} = P_{drem}, \quad (33)$$

The power production from the diesel generator unit will be null:

$$P_{dg} = 0, \quad (34)$$

Apparently, the batteries' new charge level will be equal to their nominal storage capacity:

$$E_{st} = E_{st-max}, \quad (35)$$

- b. If $E_{st}(j) \leq E_{st-max}$, then the available storage margin in the batteries is adequate for the full storage of the available power P_{RESav} ; hence, the stored power will be

$$P_{st} = P_{RESav}, \quad (36)$$

The RES power production surplus is null:

$$P_{RESsur} = 0, \quad (37)$$

Additionally, it is further investigated if the energy storage level $E_{st}(j)$ at the end of the current time calculation step j is lower than their minimum charge level E_{st-min} . Specifically, the following two sub-cases are distinguished:

- i. If $E_{st}(j) < E_{st-min}$, then the available stored energy in the batteries from the previous time step $E_{st}(j - 1)$ is not adequate for the full coverage of the remaining power demand. The power production from the batteries will be

$$P_{bat} = [E_{st}(j - 1) + P_{st} \cdot t - E_{st-min}] \cdot \eta_{dis} / t, \quad (38)$$

The diesel generator production will be

$$P_{dg} = P_{drem} - P_{bat}, \quad (39)$$

Apparently, the batteries' new charge level will be equal to their lowest charge level:

$$E_{st} = E_{st-min}, \quad (40)$$

- ii. If $E_{st}(j) \geq E_{st-min}$, then the available stored energy is enough for the full coverage of the remaining power demand. The batteries' power production will be given by the relationship 3). The diesel generator production will be null (relationship 34). The batteries' new charge level will be equal to

$$E_{st}(j) = E_{st}(j - 1) + P_{st} \cdot t \cdot \eta_{st} - P_{bat} \cdot t / \eta_{dis}, \quad (41)$$

5. For the aforementioned cases:

- The batteries' charge rate P_{st-bat} will be

$$P_{st-bat} = P_{st} \cdot \eta_{st}, \quad (42)$$

- The batteries' discharge rate $P_{dis-bat}$ will be

$$P_{dis-bat} = P_{bat} / \eta_{dis}. \quad (43)$$

5. Assumptions, Technical Features, and Economic Parameters

5.1. Technical Features

In the aforementioned algorithms, the power production from the photovoltaics and the wind turbines are involved. The power production from the photovoltaics is calculated following the essential methodology described in the relevant literature [46], together with the essential theory of solar geometry and solar radiation, which will lead to the calculation of the incident solar irradiance on the photovoltaic panels [47]. The required data are the incident solar irradiance on the horizontal plane (Figure 3), the ambient temperature (Figure 2), the wind velocity (Figure 5), and the photovoltaic panels' installation inclination versus the horizontal plane. The panels will be installed with a southern orientation. Following an iterative calculation process, summarized in Table 2, it is found that for the specific geographical location, the annual cumulative incident solar radiation is maximized for 30° inclination.

Table 2. Fluctuation of the annual cumulative incident solar radiation on a flat inclined surface at the installation location of the photovoltaic plant.

Solar Radiation Component	Inclination Angle (°)				
	20	25	30	35	40
	Annual Cumulative Solar Radiation on Flat Inclined Surface (kWh/m ²)				
Direct	973.2	992.8	1004.9	1009.3	1006.1
Indirect	675.9	664.3	651.2	634.9	616.3
Diffused	12.2	19.0	27.1	36.6	47.4
Total	1661.3	1676.1	1683.2	1680.8	1669.8

The produced electrical power from the wind turbines is simply calculated from the annual wind velocity time series at the site selected for the wind turbines' installation (Figures 5 and 7) and a typical power curve for a small wind turbine of 50 kW nominal power, as shown in Figure 10.




Figure 10. A typical adopted wind power curve for the involved 50 kW small wind turbine.

The location of the PHS installation is depicted in Figure 11, on a 3D digitized land terrain. The lower reservoir installation site is located on land previously used for mining. This means that the already formulated cavity will enable the minimization of the required excavation works, while, impacts on the natural environment are also eliminated. The absolute altitudes of the lower and the upper reservoir free surfaces are 256 m and 378 m, respectively, giving a nominal geostatic head of 122 m. The total maximum storage capacity of each tank is 25,236 m³. Given the geostatic head and the volume of the upper reservoir, the achieved storage capacity of the PHS plant is calculated at 10.5 MWh. This storage capacity, divided by the annual average daily electricity consumption (1.2 MWh, Table 1), gives an autonomy operation period of the PHS plant of 8.7 days.




Figure 11. Three-dimensional depiction of the PHS installation on a digitized land terrain.

The geometrical dimensions of the reservoirs are depicted on the typical 2D and 3D views presented in Figure 12.




Figure 12. Top view, side view, and 3D view of the reservoir.

The total length of the pipeline is calculated at 879.4 m and will consist of 151.2 m of an underground horizontal part, through a tunnel, and of 728.2 m of on-surface installation, inside a canal that will be created with excavation, and then it will be filled, to eliminate any optical deterioration of the physical landscape. Glass reinforced polyester tubes will be used, given their lower cost and anti-corrosive attributes.

Regarding the second investigated HPP layout, with electrochemical battery support, for the needs of this work, it is assumed that lithium-ion batteries will be employed, with an average charge and discharge efficiency of 90% and a maximum discharge depth kept at 80%. The selected type is the Lithium Iron Phosphate (LFP), due to its high life period and discharge depth [48].

Additionally, the life period of the lithium-ion batteries is adopted equal to 8 years, so for a total life period of the hybrid power plant of 25 years (see next Section 5.2), two replacements of the batteries should be implemented, the first one at the 9th year, and the second one at the 17th year.

Finally, regarding the operation of the thermal generator as a back-up production unit, a total efficiency of 43% is assumed, where the lowest calorific value of the consumed diesel oil is adopted equal to 10.25 kWh/L [49] and its procurement price at 0.9 EUR/L.

5.2. Economic Parameters

The sizing optimization of the examined system was based on the minimization of the LCOE, on the condition of 100% power demand coverage from the renewable energy sources. For the execution of the iterative calculations, the economic parameters presented in Table 3 were assumed, based on real quotations provided by the equipment potential manufacturers and on relevant essential market research.

Table 3. Economic parameters involved in the optimization calculation process.

Parameter	Value	
	1st HPP	2nd HPP
Wind park total setup cost (EUR/50 kW wind turbine)	180,000	
Photovoltaic plant total setup cost (EUR/kW _p)	1000	
Hydro power plant and pump station (EUR)	705,000	0
Water reservoirs (EUR/m ³)	8.8	0
Pipelines (EUR)	120,000	0
Lithium-ion batteries (EUR/kWh)	0	400
Electrical grid (EUR)	140,000	50,000
Buildings (EUR)		50,000
Several other setup costs (EUR)		50,000
Annual operation and maintenance cost (EUR/year)	10,000	5000
Lifetime period (years)		25
Discount rate (%)		4.0

The LCOE was calculated with the following relationship [50]:

$$\text{LCOE} = \frac{\left(\frac{\text{CAPEX}}{t} \text{OPEX}\right)}{E_{\text{el}}}, \quad (44)$$

where

CAPEX: the total setup of the plant;

OPEX: the annual operation and maintenance cost;

t: the lifetime period of the plant, assumed equal to 25 years;

E_{el} : the annual electricity production from the hybrid power plant, excluding the thermal generator production.

The annual operation and maintenance costs are calculated with the following relationship:

$$\text{OPEX} = C_{\text{maint}} + \frac{E_{\text{th}}}{\eta_{\text{th}} \cdot H_{\text{u}}} \cdot c_{\text{d}}, \quad (45)$$

where

C_{maint} : the annual maintenance cost, set equal to EUR 10,000;

E_{th} : the annual electricity production from the thermal generator;

η_{th} : the total efficiency of the thermal generator, set equal to 43%;

H_{u} : the lowest calorific value of diesel oil, equal to 10.25 kWh/L;

c_{d} : the diesel oil procurement price, set equal to 0.9 EUR/L.

6. Results

6.1. The Hybrid Power Plant with the PHS

An iterative calculation process was executed for different dimensioning scenarios of the plant, regarding the size of the reservoirs and the nominal capacity of the wind park and the photovoltaic station. For each one of these scenarios, the annual electricity production and storage were calculated by applying the computational simulation algorithm presented in Section 4.1. Finally, based on the aforementioned technical features and economic assumptions, the LCOE for each one of these scenarios was also calculated. The results are summarized in Table 4.

As seen in Table 4, the iterations were executed for four different sizes of the upper reservoir, starting from 30,000 m³ and ending at 15,000 m³. The capacity of 30,000 m³ was also included in the calculations just to have a clear picture of this configuration too, even though, given the available land morphology in the PHS installation site, it was selected to keep the maximum storage capacity at 25,000 m³, so as not to deteriorate considerably the natural landscape due to extensive excavation works.

We also note that this sizing optimization process has as its major target achieving 100% annual demand coverage from the RES technologies and the PHS. Obviously, a second-order criterion is the minimization of the LCOE. Given these objectives, it is seen that the optimum solution is the construction of two reservoirs with 20,000 m³ storage capacity each and the installation of two wind turbines of 50 kW each and a photovoltaic plant of 350 kW. With this scenario, the annual penetration of the hybrid power plant is 100%. and the LCOE is minimized at 0.2274 EUR/kWh. The total setup cost of the overall project is estimated at EUR 2,215,000.

The PHS setup cost is calculated as the sum of the reservoirs, the pipelines, the hydro power plant, pump station, and 50% of the connection grid setup cost. The PHS-specific setup cost is calculated by dividing the PHS setup cost by the achieved storage capacity. As seen in Table 4, the PHS-specific setup cost is calculated at 215.9 EUR/kWh of storage capacity, for the optimum size of the HPP.

Table 4. Results of the sizing optimization iteration process of the hybrid power plant with the PHS support.

	Reservoirs' Capacity (m ³)									
	30,000		25,000		20,000		15,000			
	Wind Turbines Number-Photovoltaic Nominal Power (kW _p)									
	2–300	1–300	2–250	3–300	2–300	2–350	2–350	2–350	3–300	3–350
Wind park's total initial production (kWh)	321,402	160,701	321,402	482,103	321,402	321,402	321,402	321,402	482,103	482,103
Photovoltaics' total initial production (kWh)	418,263	418,263	348,553	418,263	418,263	487,974	487,974	487,974	418,263	487,974
Direct photovoltaics' penetration (kWh)	150,380	150,380	147,015	150,380	150,380	152,836	152,836	152,836	150,380	152,836
Hydro turbines production (kWh)	283,269	260,200	281,816	283,269	282,631	280,813	280,813	279,057	282,188	280,813
Thermal generator production (kWh)	0	23,069	4818	0	638	0	0	1756	1081	0
Total RES and PHS production (kWh)	433,649	410,580	428,831	433,649	433,011	433,649	433,649	431,893	432,568	433,649
Electricity storage (kWh)	479,233	428,425	470,920	483,002	478,166	478,084	475,173	471,325	476,825	474,887
PHS annual average efficiency (%)	59.1	60.7	59.8	58.6	59.1	58.7	59.1	59.2	59.2	59.1
Total RES and PHS demand coverage percentage (%)	100.0	94.7	98.9	100.0	99.9	100.0	100.0	99.6	99.8	100.0
RES production surplus (MWh)	110,052	159	52,020	266,984	111,119	178,456	181,367	185,215	273,161	342,354
RES production surplus percentage (%)	14.9	0.0	7.8	29.7	15.0	22.0	22.4	22.9	30.3	35.3
Total setup cost (EUR)	2,385,000	2,205,000	2,335,000	2,455,000	2,275,000	2,325,000	2,215,000	2,105,000	2,235,000	2,285,000
LCOE (EUR/kWh)	0.2431	0.2373	0.2407	0.2495	0.2332	0.2375	0.2274	0.2181	0.2297	0.2338
Achieved storage capacity (kWh)	9970	9970	9970	8309	8309	8309	6647	4985	4985	4985
PHS setup cost (EUR)	1,655,000	1,655,000	1,655,000	1,545,000	1,545,000	1,545,000	1,435,000	1,325,000	1,325,000	1,325,000
Storage-plant-specific setup cost (EUR/kWh)	166.0	166.0	166.0	185.9	185.9	185.9	215.9	265.8	265.8	265.8

The optimum scenario, apart from meeting the dimensioning objectives, has two additional important positive features. Firstly, the number of installed wind turbines is only two, and, secondly, the storage capacity of the reservoirs is 20% reduced with regard to their maximum possible size at the specific site. Both these features contribute to the restriction of any potential impacts and deterioration of the natural landscape, due to the construction of the project, and will certainly facilitate the licensing process and, finally, the implementation of the plant.

In Figure 13a, the annual power production synthesis graph is presented with this first-examined HPP and for the optimum sizing scenario, while in Figure 13b,c, the power production synthesis graphs are presented from the 1st to the 10th of January and from the 11th to the 20th of August, respectively.




Figure 13. Cont.




Figure 13. (a) Annual power production synthesis graph with the first examined HPP. (b) Power production synthesis graph with the first examined HPP and from the 1st to the 10th of January. (c) Power production synthesis graph with the first examined HPP and from the 11th to the 20th of August. (d) Annual fluctuation of the daily electricity production. (e) Annual fluctuation of the water stored volume in the PHS upper reservoir.

In Figure 13d, the annual fluctuation of the daily electricity production is presented.

Finally, in Figure 13e, the annual fluctuation of the water stored volume in the PHS upper reservoir is presented.

In Table 5, the monthly aggregated electricity production is given for the involved units.

Table 5. Monthly aggregated electricity production.

Month	Monthly Production (kWh)	
	Photovoltaics Direct Penetration	Hydro Turbines
January	8606	23,174
February	9311	18,567
March	12,549	21,090
April	14,765	25,250
May	15,057	22,887
June	14,956	22,003
July	17,583	26,415
August	16,350	26,336
September	13,344	22,186
October	12,573	24,253
November	8908	21,468
December	8834	27,183
Annual sum	152,836	280,813

6.2. The Hybrid Power Plant with the Lithium-Ion Batteries

Similarly, with the HPP layout with the support of the PHS plant, in the case of the second examined layout, with the support of the lithium-ion batteries, again the optimization process was based on an iterative calculation process for different dimensioning scenarios of the plant, regarding the number of the wind turbines, the nominal power of the photovoltaic plant, and the storage capacity of the lithium-ion batteries. The optimization process was based on the computational simulation of the HPP's annual operation, following the algorithm described in Section 4.2.

Given the relatively low storage capacity of the lithium-ion batteries, imposed by their high procurement cost, the achievement of clear 100% RES penetration most probably will not be economically feasible. To examine this, the iteration process was executed with two alternative objectives:

- Firstly, the minimization of the LCOE cost, without satisfying the criterion for 100% RES penetration;
- Secondly, with the concurrent satisfaction of both criteria, namely, achievement of 100% RES penetration and minimization of the LCOE, namely, as was implemented with the first HPP.

The results of the two optimization processes are presented in Tables 6 and 7, respectively.

As seen in Table 6, the minimum LCOE, equal to 0.1096 EUR/kWh is achieved for 300 kWh of storage capacity, one wind turbine of 50 kW, and 300 kW_p of photovoltaic plant, leading to annual RES penetration of 90.2%. The annual RES production surplus is 24.7% with regard to the initial RES available electricity production. The diesel oil annual procurement cost is calculated equal to EUR 8672. The setup cost of this HPP is equal to EUR 845,915, including two battery replacements.

On the other hand, given the results presented in Table 7, the minimum required plant that gives 100% RES penetration consists of lithium-ion batteries with 2700 kWh storage capacity, two wind turbines of 50 kW nominal power each, and 500 kW_p of photovoltaic power. The total setup cost of the plant, including two battery replacements, is calculated at EUR 3,353,237. The electricity-production-specific cost is calculated equal to 0.3208 EUR/kWh, namely, 2.9 times higher than its minimum value.

Table 6. Results of the sizing optimization iteration process of the hybrid power plant with the lithium-ion support. Optimization versus the LCOE minimization.

	Lithium-Ion Batteries Storage Capacity (kWh)										
	0	200	200	300	200	200	300	300	300	300	400
	Wind Turbines		Photovoltaic		Nominal Power (kW _p)						
	1–200	1–200	2–200	2–200	1–250	1–250	1–300	2–300	1–350	2–350	2–350
Annual electricity available production from photovoltaics (kWh)	278,842	278,842	278,842	278,842	348,553	348,553	418,263	418,263	487,974	487,974	487,974
Annual electricity available production from wind turbines (kWh)	127,429	127,429	254,858	254,858	127,429	254,858	127,429	254,858	127,429	254,858	254,858
Total annual electricity available production from RES (kWh)	406,271	406,271	533,700	533,700	475,981	603,410	545,692	673,121	615,402	742,831	742,831
Annual direct electricity penetration from photovoltaics (kWh)	232,016	232,016	232,016	232,016	254,460	254,460	267,997	267,997	277,133	277,133	277,133
Annual direct electricity penetration from wind turbines (kWh)	46,080	46,080	55,402	55,402	42,314	50,365	39,717	47,027	37,923	44,724	44,724
Total annual direct electricity penetration from RES (kWh)	278,096	278,096	287,418	287,418	296,774	304,825	307,714	315,024	315,056	321,857	321,857
Annual electricity production from batteries (kWh)	0	60,130	71,748	82,155	65,377	72,914	83,465	86,548	83,587	85,574	95,233
Annual thermal generator production (kWh)	155,553	95,423	74,482	64,076	71,497	55,910	42,470	32,077	35,006	26,218	16,559
Total annual electricity production (kWh)	433,649	433,649	433,649	433,649	433,649	433,649	433,649	433,649	433,649	433,649	433,649
Annual RES contribution to power demand coverage (kWh)	278,096	338,226	359,167	369,573	362,152	377,739	391,179	401,572	398,643	407,431	417,090
Total annual RES penetration percentage (%)	64.1	78.0	82.8	85.2	83.5	87.1	90.2	92.6	91.9	94.0	96.2
Annual RES stored electricity (kWh)	0	74,168	88,517	101,331	80,646	89,957	102,943	106,755	103,094	105,553	117,446
Annual RES absorbed electricity (kWh)	278,096	352,264	375,936	388,750	377,420	394,782	410,657	421,779	418,150	427,409	439,303
Annual RES absorbed electricity percentage (%)	68.5	86.7	70.4	72.8	79.3	65.4	75.3	62.7	67.9	57.5	59.1
Annual RES electricity production surplus (kWh)	128,175	54,007	157,764	144,950	98,561	208,629	135,035	251,342	197,252	315,422	303,529
Annual RES electricity production surplus percentage (%)	31.5	13.3	29.6	27.2	20.7	34.6	24.7	37.3	32.1	42.5	40.9
Total setup cost, including battery replacements (EUR)	480,000	657,277	837,277	925,915	707,277	887,277	845,915	1,025,915	895,915	1,075,915	1,164,554
Diesel oil consumption (L)	35,293	21,650	16,899	14,538	16,222	12,685	9636	7278	7942	5949	3757
Diesel oil procurement cost (EUR)	31,764	19,485	15,209	13,084	14,600	11,417	8672	6550	7148	5354	3381
LCOE (EUR/kWh)	0.1291	0.1171	0.1238	0.1271	0.1104	0.1197	0.1096	0.1213	0.1107	0.1231	0.1267

Table 7. Results of the sizing optimization iteration process of the hybrid power plant with the lithium-ion support. Optimization versus the LCOE minimization and the 100% RES penetration.

	Lithium-Ion Batteries Storage Capacity (kW)				
	2600	2600	2700	2800	2900
	2–500	3–500	2–500	2–450	2–450
Annual electricity available production from photovoltaics (kWh)	697,105	697,105	697,105	627,395	627,395
Annual electricity available production from wind turbines (kWh)	254,858	382,287	254,858	254,858	254,858
Total annual electricity available production from RES (kWh)	951,963	1,079,392	951,963	882,252	882,252
Annual direct electricity penetration from photovoltaics (kWh)	294,030	294,030	294,030	289,600	289,600
Annual direct electricity penetration from wind turbines (kWh)	40,174	43,149	40,174	41,432	41,432
Total annual direct electricity penetration from RES (kWh)	334,204	337,179	334,204	331,032	331,032
Annual electricity production from batteries (kWh)	99,360	96,459	99,445	102,138	102,282
Annual thermal generator production (kWh)	85	11	0	479	335
Total annual electricity production (kWh)	433,649	433,649	433,649	433,649	433,649
Annual RES contribution to power demand coverage (kWh)	433,564	433,638	433,649	433,170	433,314
Total annual RES penetration percentage (%)	100.0	100.0	100.0	99.9	99.9
Annual RES stored electricity (kWh)	123,804	120,268	123,964	127,331	127,564
Annual RES absorbed electricity (kWh)	458,008	457,447	458,168	458,363	458,596
Annual RES absorbed electricity percentage (%)	48.1	42.4	48.1	52.0	52.0
Annual RES electricity production surplus (kWh)	493,955	621,945	493,795	423,890	423,656
Annual RES electricity production surplus percentage (%)	51.9	57.6	51.9	48.0	48.0
Total setup cost, including battery replacements (EUR)	3,264,598	3,444,598	3,353,237	3,391,875	3,480,514
Diesel oil consumption (L)	19	2	0	109	76
Diesel oil procurement cost (EUR)	17	2	0	98	68
LCOE (EUR/kWh)	0.3127	0.3293	0.3208	0.3246	0.3327

In Figure 14a,b, the annual power production synthesis graphs are presented for the specific HPP and for the sizing scenario with the minimum LCOE and with 100% RES penetration.




Figure 14. (a) Annual power production synthesis graph with the second examined HPP and for the sizing scenario with the minimum LCOE. (b) Annual power production synthesis graph with the second examined HPP and for the sizing scenario with 100% RES penetration.

Additionally, for the aforementioned two sizing scenarios, in Figure 15a,b, the power production synthesis graphs are presented from the 1st to the 10th of January. Similar graphs are, finally, presented in Figure 16a,b for the aforementioned two sizing scenarios and from the 11th to the 20th of August.




Figure 15. (a) Power production synthesis graph with the second examined HPP from the 1st to the 10th of January and for the sizing scenario with the minimum LCOE. (b) Power production synthesis graph with the second examined HPP from the 1st to the 10th of January and for the sizing scenario with 100% RES penetration.




Figure 16. Cont.




Figure 16. (a) Power production synthesis graph with the second examined HPP from the 11th to the 20th of August and for the sizing scenario with the minimum LCOE. (b) Power production synthesis graph with the second examined HPP from the 11th to the 20th of August and for the sizing scenario with 100% RES penetration.

In Figure 17, the monthly aggregated electricity production from the involved units is presented.




Figure 17. Annual fluctuation of the daily electricity production.

In Table 8, the monthly aggregated electricity production is given for the involved units.

Table 8. Monthly aggregated electricity production.

Month	Monthly Production (kWh)			
	Photovoltaics Direct Penetration	Wind Turbine Direct Penetration	Batteries	Thermal Generator
January	12,880	6540	8836	3524
February	15,742	3905	6701	1530
March	22,565	2753	6983	1338
April	26,188	2811	6369	4647

Table 8. Cont.

Month	Monthly Production (kWh)			
	Photovoltaics Direct Penetration	Wind Turbine Direct Penetration	Batteries	Thermal Generator
May	27,990	2157	6551	1245
June	27,927	1548	6100	1385
July	32,414	1731	7047	2805
August	30,145	2838	7017	2686
September	23,893	2228	6681	2728
October	21,041	2436	7278	6071
November	14,071	5162	7158	3986
December	13,140	5607	6745	10,525
Annual sum	267,997	39,717	83,465	42,470

7. Discussion

From the results presented in the previous section, it is concluded that 100% real-time coverage of the annual electricity demand in the Monastery with RES can be achieved, leading also to a relatively low LCOE, only with the HPP layout with the PHS. In this case, the LCOE was calculated at 0.2274 EUR/kWh, which can be considered as acceptable, particularly for the type and the circumstances of the specific case study: low power demand scale for an autonomous, non-interconnected community. The storage capacity of each one of the water reservoirs should be 20,000 m³ and the installed RES power should be 100 kW for the wind park (two wind turbines of 50 kW each) and 350 kW_p for the photovoltaic plant. The annual RES electricity surplus is 22.4%, which can also be considered as sensible. The project's total setup cost was calculated equal to EUR 2,215,000.

The achievement of 100% RES penetration with the HPP supported by electrochemical storage leads to a considerably high increase in the LCOE, at 0.3208 EUR/kWh. This is, obviously, due to the higher setup cost configured by the still high procurement prices of lithium-ion batteries. The required size of the project is defined by 2700 kWh of storage capacity, 100 kW of wind park, and 500 kW_p of photovoltaic plant. The project's total setup cost is calculated at EUR 3,353,237 (including two batteries replacements), namely, 51.4% higher than the setup of the first HPP. Finally, the annual RES electricity surplus is calculated 51.9%, precisely due to the low available storage capacity. This value cannot be accepted and constitutes another indicator, apart from the LCOE, of the low economic feasibility for the achievement of 100% RES penetration with the specific HPP layout.

On the other hand, the potentially minimum LCOE is remarkably lower than both the aforementioned LCOE values. It is achieved with the second investigated HPP, with electrochemical storage, and it was calculated equal to 0.1096 EUR/kWh. The plant's size is defined by 300 kWh of storage capacity, one wind turbine of 50 kW, and 300 kW_p of photovoltaic power. With this plant's size, the achieved annual RES penetration is 90.2% and the annual RES electricity surplus 24.7%. The annual diesel oil procurement cost, for the coverage of the remaining power demand with the thermal generator, was estimated at EUR 8672, assuming a diesel oil procurement price of 0.90 EUR/L. In this case, the project's setup cost is minimized, dropping at EUR 845,915, while the annual RES electricity surplus becomes 24.7%.

At a first glance, accounting only the minimization of the LCOE, the last-presented HPP and size should be selected. It exhibits the lowest setup cost and the lowest LCOE, and it leaves only 9.8% annual electricity demand to be produced by the thermal generator. This could be the obvious conclusion. Another advantage of this choice is that the construction of the PHS is cancelled, so any probable deterioration, even minor, of the natural landscape will be avoided.

However, particularly for Monasteries, especially in Mount Athos, it should be also taken into account that these kinds of projects are often 100% funded by funding calls or even donations from pilgrims, institutes, etc. This, practically, means that the setup

cost of the project, perhaps, does not constitute a main issue. On the contrary, regarding the economics of the project, the most important issue is to minimize the operation and maintenance cost, which should be covered every year by the Monastery's revenues. At this point, it should be clarified that the HPP, regardless the involved units and size, will not produce any kind of direct income, since the produced electricity will be exclusively used for the power demand coverage in the Monastery. Hence, the minimization of the plant's operation and maintenance cost is essential and can be achieved with the elimination of the diesel oil consumption. In this case, the HPP with the PHS is, of course, the most appropriate solution. Furthermore, this plant has also the advantage that it only needs to be constructed once, and it exhibits a long-life period, unlike electrochemical batteries, which should be replaced regularly, roughly, every 8 years, imposing a considerable periodic expense on the project's economics and creating this additional burden for the monks to seek for the required monetary amount.

Another important outcome is the storage capacity setup- or procurement-specific cost. For the selected scenario with the PHS plant, the setup-specific cost was calculated at 215.9 EUR/kWh of storage capacity. The corresponding feature of the HPP with the lithium-ion batteries was calculated at 886.4 EUR/kWh, including two replacements, for 25 years of life.

Finally, the HPP with the PHS exhibits two additional comparative important advantages. Firstly, its high added value, since all the works and the majority of the equipment can be accomplished and supplied by local experts and firms. Secondly, its long autonomy time period, which is very important regarding the security of the system. For 20,000 m³ of water storage capacity, the autonomy operation period, accounting a daily average electricity consumption of 1200 kWh, is calculated at 6.9 days. The achieved autonomy period with the lithium-ion batteries, even under the economically infeasible scenario of 100% demand coverage with 2700 kWh of storage capacity and 80% maximum discharge depth, is calculated only at 1.8 days.

8. Conclusions

This article presents a parametric study on the electricity demand coverage from renewable energy sources for small size autonomous communities, such as non-interconnected Monasteries. Two alternative hybrid power plant layouts were investigated, with the main difference being the storage plant. In the first case, a small pumped hydro storage system was employed, while in the second case, lithium-ion batteries were introduced. In both cases, small wind turbines and photovoltaics were used as electricity production units. Two different operation algorithms were also developed, adapted to the specific needs of the Monastery and the technical operational features of the involved technologies. The method was applied in the Monastery of Xenofontos, in Mount Athos.

Given the accomplished and presented work, the support of the pumped storage system offers high autonomy period (7 days) and exhibits the capacity for 100% electricity demand coverage with acceptable LCOE (0.2274 EUR/kWh). The 100% electricity demand coverage with the support of lithium-ion batteries leads to a 52% increase in the LCOE and only 1.8 days of autonomy period. If the achievement of 100% annual electricity demand coverage from renewables is not crucial, then the HPP with the electrochemical battery support exhibits the minimum LCOE, equal to 0.1096 EUR/kWh and 90% annual renewables penetration.

The study proves the technical and economic feasibility for the power demand coverage with hybrid power plants in cases of autonomous, rural communities, and a very low demand scale. If there is favorable land morphology at the installation site, the introduction of a small size pumped storage system can be feasible. Electrochemical batteries can be the optimum solution if the annual renewables penetration percentage is acceptable to remain in the range of 90% and the annual expense of the diesel oil procurement can be affordable. This, however, may not be the case, particularly for Monasteries, where the setup cost of

such systems is most likely to be covered by subsidies and donations, whereas, on the contrary, the annual operation cost should be covered by any potential regular incomes.

Pumped storage plants also have the comparative advantages of higher added value and long autonomy periods. On the other hand, the required technical work for the installation of a pumped storage system will surely impose a larger impact on the local landscape aesthetics, which, depending on the specific case, may not be acceptable.

The results of this study are highly applicable to similar cases of remote and rural insular or agricultural communities and very low power demand scale.

Funding: This research received no external funding.

Institutional Review Board Statement: Not applicable.

Informed Consent Statement: Not applicable.

Data Availability Statement: The data presented in this study are available on request from the corresponding author. The data are not publicly available due to privacy restrictions.

Conflicts of Interest: The author declares no conflicts of interest.

Abbreviations

CAES	Compressed Air Energy Storage
ECMWF	European Centre for Medium-Range Weather Forecasts
EMS	Energy Management System
HPP	Hybrid Power Plant
LCOE	Levelized Cost Of Electricity
LFP	Lithium Iron Phosphate
PHS	Pumped Hydro Storage
RES	Renewable Energy Sources

References

1. Agajie, T.F.; Fopah-Lele, A.; Ali, A.; Amoussou, I.; Khan, B.; Elsis, M.; Mahela, O.M.; Álvarez, R.M.; Tanyi, E. Optimal Sizing and Power System Control of Hybrid Solar PV-Biogas Generator with Energy Storage System Power Plant. *Sustainability* **2023**, *15*, 5739. [[CrossRef](#)]
2. Sambhi, S.; Sharma, H.; Bhadoria, V.; Kumar, P.; Chaurasia, R.; Fotis, G.; Vita, V. Technical and Economic Analysis of Solar PV/Diesel Generator Smart Hybrid Power Plant Using Different Battery Storage Technologies for SRM IST, Delhi-NCR Campus. *Sustainability* **2023**, *15*, 3666. [[CrossRef](#)]
3. Gomes, J.G.; Jiang, J.; Chong, C.T.; Telhada, J.; Zhang, X.; Sammarchi, S.; Wang, S.; Lin, Y.; Li, J. Hybrid solar PV-wind-battery system bidding optimisation: A case study for the Iberian and Italian liberalised electricity markets. *Energy* **2023**, *263*, 126043. [[CrossRef](#)]
4. Li, R.; Jin, X.; Yang, P.; Sun, X.; Zhu, G.; Zheng, Y.; Zheng, M.; Wang, L.; Zhu, M.; Qi, Y.; et al. Techno-economic analysis of a wind-photovoltaic-electrolysis-battery hybrid energy system for power and hydrogen generation. *Energy Convers. Manag.* **2023**, *281*, 116854. [[CrossRef](#)]
5. Ngouleu, C.A.W.; Koholé, Y.W.; Fohagui, F.C.V.; Tchien, C. Techno-economic analysis and optimal sizing of a battery-based and hydrogen-based standalone photovoltaic/wind hybrid system for rural electrification in Cameroon based on meta-heuristic techniques. *Energy Convers. Manag.* **2023**, *280*, 116794. [[CrossRef](#)]
6. Katsaprakakis, D.; Dakanali, I. Comparing electricity storage technologies for small insular grids. *Energy Procedia* **2019**, *159*, 84–89. [[CrossRef](#)]
7. González-Ramírez, J.M.; Arcos-Vargas, Á.; Núñez, F. Optimal sizing of hybrid wind-photovoltaic plants: A factorial analysis. *Sustain. Energy Technol. Assess.* **2023**, *57*, 103155. [[CrossRef](#)]
8. Al-Ghussain, L.; Ahmad, A.D.; Abubaker, A.M.; Hovi, K.; Hassan, M.A.; Annuk, A. Techno-economic feasibility of hybrid PV/wind/battery/thermal storage trigeneration system: Toward 100% energy independency and green hydrogen production. *Energy Rep.* **2022**, *9*, 752–772. [[CrossRef](#)]
9. Ourya, I.; Nabil, N.; Abderafi, S.; Boutammachte, N.; Rachidi, S. Assessment of green hydrogen production in Morocco, using hybrid renewable sources (PV and wind). *Int. J. Hydrog. Energy* **2023**, *48*, 37428–37442. [[CrossRef](#)]
10. Al-Masri, H.M.K.; Al-Sharqi, A.A.; Magableh, S.K.; Al-Shetwi, A.Q.; Abdolrasol, M.G.M.; Ustun, T.S. Optimal Allocation of a Hybrid Photovoltaic Biogas Energy System Using Multi-Objective Feasibility Enhanced Particle Swarm Algorithm. *Sustainability* **2022**, *14*, 685. [[CrossRef](#)]

11. El-Sattar, H.A.; Sultan, H.M.; Kamel, S.; Khurshaid, T.; Rahmann, C. Optimal design of stand-alone hybrid PV/wind/biomass/battery energy storage system in Abu-Monqar, Egypt. *J. Energy Storage* **2021**, *44*, 103336. [[CrossRef](#)]
12. Kapen, P.T.; Nouadje, B.A.M.; Chegnimonhan, V.; Tehuen, C.; Tchinda, R. Techno-economic feasibility of a PV/battery/fuel cell/electrolyzer/biogas hybrid system for energy and hydrogen production in the far north region of cameroon by using HOMER pro. *Energy Strategy Rev.* **2022**, *44*, 100988. [[CrossRef](#)]
13. Katsaprakakis, D.A.; Moschovos, T.; Michopoulos, A.; Kargas, I.D.; Flabouri, O.; Zidianakis, G. Feasibility for the introduction of decentralised combined heat and power plants in agricultural processes. A case study for the heating of algae cultivation ponds. *Sustain. Energy Technol. Assess.* **2022**, *53*, 102757.
14. Algieri, A.; Morrone, P. Thermo-economic investigation of solar-biomass hybrid cogeneration systems based on small-scale transcritical organic Rankine cycles. *Appl. Therm. Eng.* **2022**, *210*, 118312. [[CrossRef](#)]
15. Fan, W.; Huang, L.; Tan, Z.; Xue, F.; De, G.; Song, X.; Cong, B. Multi-objective Optimal Model of Rural Multi-energy Complementary System with Biogas Cogeneration and Electric Vehicle Considering Carbon Emission and Satisfaction. *Sustain. Cities Soc.* **2021**, *74*, 103225. [[CrossRef](#)]
16. Isa, N.M.; Tan, C.W.; Yatim, A.H.M. A comprehensive review of cogeneration system in a microgrid: A perspective from architecture and operating system. *Renew. Sustain. Energy Rev.* **2018**, *81*, 2236–2263. [[CrossRef](#)]
17. Zailan, R.; Lim, J.S.; Manan, Z.A.; Wan Alwi, S.R.; Mohammadi-Ivatloo, B.; Jamaluddin, K. Malaysia scenario of biomass supply chain-cogeneration system and optimization modeling development: A review. *Renew. Sustain. Energy Rev.* **2021**, *148*, 111289. [[CrossRef](#)]
18. Arnaoutakis, G.E.; Kocher-Oberlehner, G.; Katsaprakakis, D.A. Criteria-Based Model of Hybrid Photovoltaic–Wind Energy System with Micro-Compressed Air Energy Storage. *Mathematics* **2023**, *11*, 391. [[CrossRef](#)]
19. Zhao, P.; Xu, W.; Zhang, S.; Wang, J.; Dai, Y. Technical feasibility assessment of a standalone photovoltaic/wind/adiabatic compressed air energy storage based hybrid energy supply system for rural mobile base station. *Energy Convers. Manag.* **2020**, *206*, 112486. [[CrossRef](#)]
20. Karaca, A.E.; Dincer, I.; Nitefor, M. A new renewable energy system integrated with compressed air energy storage and multistage desalination. *Energy* **2023**, *268*, 126723. [[CrossRef](#)]
21. Wu, Y.; Zhang, T.; Xu, C.; Zhang, B.; Li, L.; Ke, Y.; Yan, Y.; Xu, R. Optimal location selection for offshore wind-PV-seawater pumped storage power plant using a hybrid MCDM approach: A two-stage framework. *Energy Convers. Manag.* **2019**, *199*, 112066. [[CrossRef](#)]
22. Nassar, Y.F.; Abdunnabi, M.J.; Sbeta, M.N.; Hafez, A.A.; Amer, K.A.; Ahmed, A.Y.; Belgasim, B. Dynamic analysis and sizing optimization of a pumped hydroelectric storage-integrated hybrid PV/Wind system: A case study. *Energy Convers. Manag.* **2020**, *229*, 113744. [[CrossRef](#)]
23. Zhang, Z.; Xu, D.; Chan, X.; Xu, G. Research on Power System Day-Ahead Generation Scheduling Method Considering Combined Operation of Wind Power and Pumped Storage Power Station. *Sustainability* **2023**, *15*, 6208. [[CrossRef](#)]
24. Katsaprakakis, D.A.; Christakis, D.G. A wind parks, pumped storage and diesel engines power system for the electric power production in Astypalaia. In Proceedings of the European Wind Energy Conference and Exhibition 2006 (EWEC 2006), Athens, Greece, 27 February–2 March 2006; pp. 621–636.
25. Pradhan, A.; Marence, M.; Franca, M.J. The adoption of Seawater Pump Storage Hydropower Systems increases the share of renewable energy production in Small Island Developing States. *Renew. Energy* **2021**, *177*, 448–460. [[CrossRef](#)]
26. Katsaprakakis, D.A.; Christakis, D.G. Maximisation of R.E.S. penetration in Greek insular isolated power systems with the introduction of pumped storage systems. In Proceedings of the European Wind Energy Conference and Exhibition 2009 (EWEC 2009), Marseille, France, 16–19 March 2009; Volume 7, pp. 4918–4930.
27. Briongos, F.; Platero, C.A.; Sánchez-Fernández, J.A.; Nicolet, C. Evaluation of the Operating Efficiency of a Hybrid Wind–Hydro Powerplant. *Sustainability* **2020**, *12*, 668. [[CrossRef](#)]
28. Ioakimidis, C.S.; Genikomsakis, K.N. Integration of Seawater Pumped-Storage in the Energy System of the Island of São Miguel (Azores). *Sustainability* **2018**, *10*, 3438. [[CrossRef](#)]
29. Lopes, A.S.; Castro, R.; Silva, C.S. Design of water pumped storage systems: A sensitivity and scenario analysis for island microgrids. *Sustain. Energy Technol. Assess.* **2020**, *42*, 100847.
30. Hyrzyński, R.; Ziółkowski, P.; Gotzman, S.; Kraszewski, B.; Ochrymiuk, T.; Badur, J. Comprehensive thermodynamic analysis of the CAES system coupled with the underground thermal energy storage taking into account global, central and local level of energy conversion. *Renew. Energy* **2021**, *169*, 379–403. [[CrossRef](#)]
31. Soltani, M.; Kashkooli, F.M.; Jafarizadeh, H.; Hatefi, M.; Fekri, H.; Gharali, K.; Nathwani, J. Diabatic Compressed Air Energy Storage (CAES) Systems: State of the Art. *Encycl. Energy Storage* **2022**, *2*, 173–187.
32. Zhao, Z.; Yuan, Y.; He, M.; Jurasz, J.; Wang, J.; Egusquiza, M.; Egusquiza, E.; Xu, B.; Chen, D. Stability and efficiency performance of pumped hydro energy storage system for higher flexibility. *Renew. Energy* **2022**, *199*, 1482–1494. [[CrossRef](#)]
33. Mahfoud, R.J.; Alkayem, N.F.; Zhang, Y.; Zheng, Y.; Sun, Y.; Alhelou, H.H. Optimal operation of pumped hydro storage-based energy systems: A compendium of current challenges and future perspectives. *Renew. Sustain. Energy Rev.* **2023**, *178*, 113267. [[CrossRef](#)]
34. Jubeh, N.M.; Najjar, Y.S.H. Green solution for power generation by adoption of adiabatic CAES system. *Appl. Therm. Eng.* **2012**, *44*, 85–89. [[CrossRef](#)]

35. Yu, H.; Engelkemier, S.; Gençer, E. Process improvements and multi-objective optimization of compressed air energy storage (CAES) system. *J. Clean. Prod.* **2021**, *335*, 130081. [[CrossRef](#)]
36. Karellas, S.; Tzouganatos, N. Comparison of the performance of compressed-air and hydrogen energy storage systems: Karpathos island case study. *Renew. Sustain. Energy Rev.* **2014**, *29*, 865–882. [[CrossRef](#)]
37. Jahangir, M.H.; Cheraghi, R. Economic and environmental assessment of solar-wind-biomass hybrid renewable energy system supplying rural settlement load. *Sustain. Energy Technol. Assess.* **2020**, *42*, 100895. [[CrossRef](#)]
38. Soliman, A.M.; Alharbi, A.G.; Sharaf Eldean, M.A. Techno-Economic Optimization of a Solar–Wind Hybrid System to Power a Large-Scale Reverse Osmosis Desalination Plant. *Sustainability* **2021**, *13*, 11508. [[CrossRef](#)]
39. Carroquino, J.; Bernal-Agustín, J.L.; Dufo-López, R. Standalone Renewable Energy and Hydrogen in an Agricultural Context: A Demonstrative Case. *Sustainability* **2019**, *11*, 951. [[CrossRef](#)]
40. European Centre for Medium-Range Weather Forecasts (ECMWF): ERA5 from the Copernicus Climate Change Service (C3S) Climate Data Store. ERA5 Hourly Data on Single Levels from 1959 to Present. Available online: <https://cds.climate.copernicus.eu/#!/search?text=ERA5&type=dataset> (accessed on 19 April 2023).
41. Kalmikov, A. Chapter 2—Wind Power Fundamentals. In *Wind Energy Engineering. A Handbook for Onshore and Offshore Wind Turbines*; Elsevier: Amsterdam, The Netherlands, 2017; pp. 17–24.
42. DTU Wind and Energy Systems: WASP. Available online: <https://www.wasp.dk/wasp> (accessed on 19 April 2023).
43. Gouveia, J.; Moreira, C.L.; Peças Lopes, G.A. Improving Dynamic Security in Islanded Power Systems: Quantification of Minimum Synchronous Inertia Considering Fault-Induced Frequency Deviations. *Electricity* **2023**, *4*, 114–133. [[CrossRef](#)]
44. Gayathri, K.; Jena, M.K.; Moharana, A.K. Impact of Different Penetration Level of Type-IV Renewable Energy Resources on Power System Dynamics. In Proceedings of the 2021 9th IEEE International Conference on Power Systems (ICPS), Kharagpur, India, 16–18 December 2021; pp. 1–6.
45. Impram, S.; Nese, S.V.; Oral, B. Challenges of renewable energy penetration on power system flexibility: A survey. *Energy Strategy Rev.* **2020**, *31*, 100539. [[CrossRef](#)]
46. Fragkiadakis, I. *Photovoltaic systems*, 4th ed.; Ziti Editions: Athens, Greece, 2019.
47. Kreider, J.; Rabl, A.; Curtiss, P. *Heating and Cooling of Buildings*, 3rd ed.; CRC Press: Boca Raton, FL, USA, 2017.
48. Eco Tree Lithium. What Are the Different Types of Lithium Batteries? Available online: <https://ecotreelithium.co.uk/news/lithium-batteries-types/> (accessed on 23 February 2024).
49. Directive on Buildings’ Energy Performance. Official Governmental Gazette 2367B’/12-7-2017. Available online: http://tdm.tee.gr/wp-content/uploads/2017/07/fek_12_7_2017_egrisi_kenak.pdf (accessed on 23 February 2024).
50. Barasa Kabeyi, M.J.; Olanrewaju, O.A. The levelized cost of energy and modifications for use in electricity generation planning. *Energy Rep.* **2023**, *9*, 495–534. [[CrossRef](#)]

Disclaimer/Publisher’s Note: The statements, opinions and data contained in all publications are solely those of the individual author(s) and contributor(s) and not of MDPI and/or the editor(s). MDPI and/or the editor(s) disclaim responsibility for any injury to people or property resulting from any ideas, methods, instructions or products referred to in the content.