

*Sustainability* **2015**, *7*, 13904–13919; doi:10.3390/su71013904 This paper has been retracted. A Retraction notice was published on 22 April 2016 at *Sustainability* **2016**, *8*, 401; doi:10.3390/su8040401.

OPEN ACCESS

*sustainability*

ISSN 2071-1050

www.mdpi.com/journal/sustainability

Article

## RETRACTED: A New Method to Energy Saving in a Micro Grid

Andrea Vallati \*, Stefano Grignaffini † and Marco Romagna †

Department of Astronautic, Electric and Energetic Engineering, “Sapienza” University of Rome, via Eudossiana 18, 00184 Rome, Italy; E-Mails: stefano.grignaffini@uniroma1.it (S.G.), marco.romagna@uniroma1.it (M.R.)

† These authors contributed equally to this work.

\* Author to whom correspondence should be addressed; E-Mail: andrea.vallati@uniroma1.it; Tel.: +39-06-44585664; Fax: +39-064-880-120.

Academic Editors: Marc A. Rosen, Francesco Asdrubali and Pietro Buzzini

Received: 11 June 2015 / Accepted: 9 October 2015 / Published: 15 October 2015

**Abstract:** Optimization of energy production systems is a relevant issue that must be considered in order to follow the fossil fuels consumption reduction policies and CO<sub>2</sub> emission regulation. Increasing electricity production from renewable resources (e.g., photovoltaic systems and wind farms) is desirable but its unpredictability is a cause of problems for the main grid stability. A system with multiple energy sources represents an efficient solution, by realizing an interface among renewable energy sources, energy storage systems, and conventional power generators. Direct consequences of multi-energy systems are a wider energy flexibility and benefits for the electric grid, the purpose of this paper is to propose the best technology combination for electricity generation from a mix of renewable energy resources to satisfy the electrical needs. The paper identifies the optimal off-grid option and compares this with conventional grid extension, through the use of HOMER software. The solution obtained shows that a hybrid combination of renewable energy generators at an off-grid location can be a cost-effective alternative to grid extension and it is sustainable, techno-economically viable, and environmentally sound. The results show how this innovative energetic approach can provide a cost reduction in power supply and energy fees of 40% and 25%, respectively, and CO<sub>2</sub> emission decrease attained around 18%. Furthermore, the

multi-energy system taken as the case study has been optimized through the utilization of three different type of energy storage (Pb-Ac batteries, flywheels, and micro—Compressed Air Energy Storage (C.A.E.S.)).

**Keywords:** multi-energy system; cost of energy; energy storage

---

## 1. Introduction

With about 1.3 billion people in the world (or about one in five) without access to electricity in 2010, the challenge of providing reliable and cost-effective services remains one of the major global challenges facing the world in this century. Although grid extension still remains the preferred mode of rural electrification [1], extension of the central electricity grid to geographically remote and sparsely populated rural areas can either be financially unviable or practically infeasible. Off-grid options can be helpful in such cases. Moreover, the efforts in using renewable energies have often focused on single technologies. Reliance on a single technology generally results in an over-sizing of the system, thereby increasing the initial costs. A hybrid system design can overcome the intermittent nature of renewable energy sources (RES), the over-sizing issue and enhance reliability of supply; thus, hybrid systems have received limited attention due to their increased complexity and hardly any work has considered the issue of reliable supply of electricity.

Moreover, the actual problems are about the energy saving and the emission of CO<sub>2</sub> into the atmosphere. For these topics the international community set a deadline to achieve some targets in the Kyoto Protocol. The European Union accepted the recommendations established in the agreement and it has outlined a strategy in order to achieve three different targets (called 20-20-20) by 2020: the 20% reduction of greenhouse gases emissions, the 20% increase of energy production from renewable sources, and the 20% increase of energy efficiency [2,3]. The following guidelines have been outlined: promoting the electricity distribution grid with generators connected, incentivizing the energy production from renewable sources and from combined heat and power systems (CHP) applied in residential, service, and commercial sectors, developing the sustainable mobility through the utilization of electric vehicles, promoting a rational use of electricity in order to decrease the energy consumption. For this reason, it is necessary to study multi-energy or hybrid systems: systems which use two or more energy sources, energy converters, or fuels [4] in order to meet the energy demand of a user which can be a single building, a group of buildings or a factory. These systems are inherently flexible and allow exploitation of the renewable sources in the best way, following thermal and electric demands, increasing the reliability of service continuity through the utilization of CHP generators, and reducing operation costs. Multi-energy systems play a crucial role in a political context inclined to the distributed generation. It is possible to control the power production and energy demand providing a valuable contribution to the stabilization of the electric main grid, by including energy storage systems and diesel technologies.

In the literature there are few articles studying the problem of multi-energy systems [5]. The design of multi-energy systems is becoming an important topic [6], driven in part by the need to integrate

distributed energy sources. Effective integration requires the balancing of demand and supply in geographic and temporal terms, which can be aided by computational methods.

It has been demonstrated that an efficient energy-hub produces a remarkable reduction of costs, greenhouse gases emissions and energy saving [7]. The energy-hub is considered as unit where the energetic flows are converted, conditioned, and eventually stored [8]; as input it requires an amount of energy (electric energy from the grid, natural gas, energy from renewable sources) and it ensures the supply for several services, such as: electric and thermal energy, cooling, compressed air, *etc.* The redundant connections that could be established between input and output inside the energy-hub have two significant consequences: an increase of reliability of resources supply and the most advantageous choice among the various options. Brenna *et al.* [9] proposed a model that allows integration between different independent subsystems, such as final users and high efficiency buildings, with CHP in a Sustainable Energy Microsystem (SEM), aimed at the management of the city of the future, the smart-city. It is necessary to communicate with a “smart grid” by exchanging information and by controlling the energy flows, in order to produce: an increase of energy saving, a reduction of pollutant emissions, the possibility of realize stand-alone systems, relieving congestion in the electric grid during the peak hours of the day [10].

Early examples using the energy hub approach address simple generic hub layouts where energy sources, such as natural gas and electricity are integrated [11,12]. The energy hub is represented as a single entity containing all conversion and storage technologies, which supplies electricity, heating, and cooling at the output ports of the hub. Examples which address real case studies include studies of energy hubs in Baden Dätwil, Switzerland and in Waterloo, Canada [13].

The technologies considered are typically centralized energy systems based on gas and electricity. Nazar *et al.* [14] used the energy hub approach to optimize an urban electricity distribution system for investment costs, operational costs and system availability. Pazouki *et al.* [15] addressed uncertainties during the operation of an energy hub incorporating wind turbines and storage technologies. La Scala *et al.* [16] addressed 24 multi-energy hubs connected with electricity and gas networks.

Givler and Lilienthal [17] conducted a case study of Sri Lanka where they identified when a PV/diesel hybrid becomes cost effective compared to a stand-alone small solar home systems (50 W PV with battery). This study considers an individual household base load of 5 W with a peak of 40 W, leading to a daily load average of 305 kWh. Through a large number of simulations, the study found that the PV-diesel hybrid becomes cost effective as the demand increases.

Hafez and Bhattacharya [18] analyzed the optimal design and planning of renewable energy-based micro-grid systems for a hypothetical rural community where the base load is 600 kW and the peak load is 1183 kW, with a daily energy requirement of 5000 kWh/day. The study considers solar, wind, hydro, and diesel resources for electricity generation. Although the study considers electricity demand over 24 h, the purely hypothetical nature of the assumptions make the work unrealistic for many off-grid areas of developing countries.

Similar case studies are presented in other studies as well. For example, Himri *et al.* [19] present a study of an Algerian village; Nandi and Ghosh [20] discuss the case of a Bangladeshi village, while Nfah *et al.* [21] and Bekele and Palm [22] provide case studies of Cameroon and Ethiopia, respectively.

The aim of this study is to evaluate a multi-energy system through a transient analysis of performance, in order to obtain a primary energy saving, a reduction of operating costs and CO<sub>2</sub>

emissions, compared to a conventional plant. It will be also shown how the various plant components must operate in order to obtain the desired savings. Moreover, three different kinds of electric storage will be considered, in order to evaluate their impact by changing key parameters. An economic and financial assessment will be carried out in order to verify the investment feasibility, which is the necessary condition for the plant realization.

The innovative idea is to use two mathematical models, one to optimize the thermal and electrical loads and the other one to optimize the plant configuration in terms of economic and financial aspects.

## 2. Numerical Model

In this paper a new method to optimize a multi-energy system is proposed: the analysis and optimization through the utilization of two different models in cascade. The study of heat exchanges and electricity loads is performed using the software TRNSYS [23]; the obtained results are used as inputs for Homer Energy [24] that is used to perform the energetic optimization process and to evaluate the economic benefit of the investment.

TRNSYS is a transient system simulation software that has been designed for the simulation of thermal and electrical energy systems. Its modular architecture allows the implementation of new components and mathematical models, and a large number of user defined “types” have been generated for various purposes. It can be used for detailed thermal modeling (solar thermal collectors, combustions furnaces, heat pumps, fuel cells) and electrical modeling (photovoltaics, wind turbine, co-generation) as well as district heating networks, seasonal storage, and detailed building energy simulation. The software is designed for detailed energy system simulations and is not suitable for modeling general energy flows at district or city levels, and it is not able to model air flows.

HOMER (Hybrid Optimisation Model for Electric Renewables), developed by NREL (National Renewable Energy Laboratory, USA) appears repeatedly in the literature as a preferred tool. It can handle a large set of technologies (including PV, wind, hydro, fuel cells, and boilers), loads (AC/DC, thermal and hydrogen), and can perform hourly simulations. HOMER is an optimization tool that is used to decide the system configuration for decentralized systems. It has been used both to analyze the off-grid electrification issues in the developed, as well as developing, countries.


The implemented model is based on the time series: for every time step the model solves the energy balance for each component and correlates it with the other components of the same system. For each component, the model evaluates the costs of energy production, giving priority to the lower ones. The evaluation of the costs is carried out considering the cost of investment, maintenance, and fuel purchase.

## 3. Case Study

In this paper a study to improve the energy efficiency of the industrial site with high power consumption is proposed, using a multi energy system.

The building is characterized by a surface area of 1600 m<sup>2</sup> and a volume of 8000 m<sup>3</sup> and large spaces around allow different types of plant installations. Actually, the energy plant is constituted by a diesel fired boiler (400 kW) for the heating and hot water production, and two refrigeration units (each one 140 kW). The energy demand of the building during the year has been studied, through a transient

analysis and utilizing the results of previous papers [25–29]. Figure 1 and Table 1 show the thermal and cooling loads of the case study.




**Figure 1.** Yearly trend of energy demand for heating (Q heat) and cooling (Q cool), obtained with TRNSYS.

**Table 1.** Yearly total energy demand (kWh/year) for heating and cooling.


Energy Demand (kWh/Year)	
Heating (kWh/year)	179,228
Cooling (kWh/year)	45,932

Figure 2 shows the trend of electric power absorbed from the grid during the year; it can be observed that the electricity demand is continuous; the average value is 150 kW and total electricity demand during the year is 1,315,624 kWh. The cost of energy consumption and diesel oil purchase, in 2012, has been €268,942; the Net Present Cost for 20 years of operation is €3573.82 and the yearly CO<sub>2</sub> emission is 765.7 ton/year.




**Figure 2.** Yearly trend of electricity purchased from the grid.

In order to obtain a reduction of fuel consumption, cost of energy and CO<sub>2</sub> emissions, the implementation of a multi-energy system has been proposed (Figure 3). It consists of a CHP reciprocating internal combustion engine and photovoltaic panels (100 kWp); the engine is supplied by natural gas that has a lower carbon content compared to diesel fuel. The thermal load is satisfied by a CHP engine and by an integrated boiler fueled by natural gas. The price of natural gas, considering the tax relief, is 0.469 €/nm<sup>3</sup>; the price of electricity depends by the time slot (0.18 €/kWh, 0.15 €/kWh and 0.10 €/kWh). For generators characterized by an electric capacity lower than 200 kW, it is possible to carry out the on-site exchange, by inserting into the grid the excess electric production; the sale price has been set at 0.09 €/kWh. The unit costs of the components are: for photovoltaic panels, 2500 €/kW, for the inverter, 300 €/kW, for the CHP engine, 1500 €/kW. For the optimization process, several simulations have been considered in order to compare three different sizes of CHP engine (100 kW, 150 kW, and 200 kW). Regarding the electric power absorbed from the grid, two constraints have been imposed: 100 kW and 150 kW, which obviously have an influence on operating hours of the generator. Therefore, six simulations have been performed. Figure 4 shows the Net Present Cost for each configuration considered and for the current plant. It can be observed that there are no remarkable differences among the six configurations; even though Configurations 4 and 6 are characterized by the highest cost of investment, they have also the highest profits due to the increase of self-generated energy. In fact, in Italy, self-generated energy is promoted by the Authority of Energy through the sale of “Certificati Bianchi”. This economic item is very important to prepare the final business plan of the plant system.



**Figure 3.** Multi-energy system implemented in Homer Energy.




**Figure 4.** Net Present Cost of the configurations considered and the current plant.

From the economic point of view, Configuration 1 is the best, followed by Configuration 4, which is a compromise between all the configurations. In Table 2 and in Figure 5 the distribution of electricity production for the six configurations considered is shown; as it can be seen, for Configurations 1, 2, and 3, the amount of energy purchased from the grid is approximately 50%, while for Configurations 4, 5, and 6 it tends to decrease up to 11%.

**Table 2.** Configurations considered.

Configuration	CHP (kW)	Grid (kW)
1	100	150
2	150	150
3	100	100
4	200	150
5	150	100
6	200	100




**Figure 5.** Distribution of electricity production for the six configurations.


Once again, two different scenarios are proposed: for the first three configurations, there is a strong dependence on the price of electricity, on the other hand, Configurations 5 and 6 are characterized by a



strong dependence of natural gas price; Configuration 4 represents a good compromise among the others. From thermal point of view, it can be observed how the CHP supplies the thermal load (Figure 6); in all configurations there is a sufficient production of heat and the use of boiler is mainly concentrated in the hours when the CHP is off. Even in Configuration 1, where CHP size is 100 kW, the heat produced by the boiler is less than 20%. Figure 7 shows the value of the Cost of Energy for the various configurations considered and for the current plant; the COE of Configuration 6 is lower ( $COE_6 = 0.133 \text{ €/kWh}$ ), which corresponds to the maximum production of electricity. However, the Cost of Energy of Configuration 4 ( $COE_4 = 0.135 \text{ €/kWh}$ ) is very similar to the lowest one; considering the Net Present Cost (Figure 4b) and the Cost of Energy, Configuration 4 is preferred over the Configuration 6. In Figure 8 the  $CO_2$  emissions for the configurations, are shown; it is calculated as the sum of the part emitted by the internal combustion engine and the one related to the electricity absorbed by the main grid, through the emission factor of the Italian grid that is  $523 \text{ g/kWh}$ .




**Figure 6.** Thermal load distribution for the six configurations considered.



**Figure 7.** Cost of Energy for the six configuration considered and the current plant.





**Figure 8.** CO<sub>2</sub> emissions for the six configurations considered and the current plant.

Therefore, Configuration 4 represents a good compromise with a low COE, which is much lower than the one of the current plant (COE<sub>cp</sub> = 0.170 €/kWh); the limitation of the electrical absorption at 150 kW is a preferable solution for the CHP, which works for less hours per year, compared with Configuration 6, determining a decrease of costs of maintenance and natural gas consumption. The benefits of Configuration 4, compared to the current plant, are: an energy saving of 97,500 €/year, a decrease of COE from 0.170 €/kWh to 0.135 €/kWh and a decrease of CO<sub>2</sub> emissions of 139 Mg/year. The Primary Energy Saving (PES) index, expressed in Equation (1), for Configuration 4 is 34.5%, equivalent to 71.6 TOE.

$$PES = \left( 1 - \frac{1}{\frac{\eta_{CHP,elec}}{\eta_{ref,elec}} + \frac{\eta_{CHP,therm}}{\eta_{ref,therm}}} \right) \cdot 100\% \quad (1)$$


#### 4. Multi-Energy System with Electric Storage

In the next few years, a quick and extensive diffusion of energy storage systems, is expected. Conventional power plants are forced to operate following the fluctuations of the electric load, determining the instability of the main grid, because of the increase of energy production from renewable sources and to their non-programmability. The storage system represents a solution for this problem, by: limiting the effects of intermittency [30], separating the time energy production from renewable sources and its consumption and leveling the energy dispatched to the grid. Moreover, in countries where the difference of cost of energy is high, between the peak hours, and the night hours, the possibility of making profits is realistic [31]. In this study, an evaluation of the effects produced by the adoption of three different energy storage system, has been performed. The systems considered are: the Pb-Ac batteries [32], which represent a proven and reliable technology, even if they are characterized by a short life and a low efficiency; the flywheels, which are kinetic energy storage systems characterized by a high efficiency and a high unit cost; the micro-CAES, characterized by low efficiency, an intermediate unit cost, and long life [33]. In Table 3 the characteristics of the three storage systems are shown [34], and in Figure 9 the configuration plant with the Pb-Ac, flywheels, and Micro-CAES are shown. For each technology of storage system, several sizes (electric capacities) have been considered: 25 kWh, 50 kWh, 100 kWh, 150 kWh, and 200 kWh, in order to evaluate their


effects on the energetic and economic parameters and to optimize the system. In Figure 10 are shown the Cost of Energy (Figure 10a) and the Operating Cost (Figure 10b) of the multi-energy system, using different sizes of each storage system, compared with the values (continuous lines) without the energy storage. As it can be seen, the multi-energy system equipped with micro-CAES or Pb-Ac batteries, has a competitive Cost of Energy up to the size of 100 kWh, while the flywheel system is disadvantaged by its high cost of investment.

**Table 3.** Characteristics of the three storage systems considered.

Electric Storage	Efficiency (%)	Life (Year)	Unit Cost (€/kW)
Pb-Ac	75	5 ÷ 10	200
Flywheel	92	>20	2000
Caes	63	>20	700




**Figure 9.** Configuration plant of the multi-energy system with the three storage systems considered.




**Figure 10.** Cost of Energy (a) and Operating Cost (b) of the multi-energy systems with different sizes of each storage systems, compared with the values (continuous lines) without storage systems.


The annual operating costs for electricity and heat supply are lower for each size of micro-CAES considered and for flywheels, up to the size of 100 kWh. These trends are due to operation of the storage system: during the evening and the night it is charged, while it is discharged during the hours when the cost of electricity is high. In Figure 11 the daily charge/discharge trends of each storage system considered (size 50 kWh) are shown. As can be noticed (Figure 12) the model prefers to discharge the storage system during the central hours of the day or when the photovoltaic production decreases, causing a time-shift of the peak of electric power requested from the grid (as shown in Figure 12). It produces benefits for the main grid, which is particularly congested during the central hours of the day, when industrial plants and most of the users are fully operative.



(a)




(b)



(c)

**Figure 11.** Daily charge/discharge trends (battery state of charge during a day) for the three storage systems, characterized by a size of 50 kWh: (a) Pb-Ac batteries; (b) flywheels; (c) micro-CAES.



**Figure 12.** Operation time series for each component of the multi-energy systems, equipped with a Pb-Ac (50 kWh), during a summer day.

## 5. Conclusions

In order to face the increasing growth of energy consumption of modern society and to reduce the emissions of greenhouse gases in compliance with international agreements, the problem of energy saving related to the responsible utilization of the energy sources is becoming important. The energy upgrading of existing buildings can represent a valid contribution. In this study, a method for the energy upgrading has been proposed; an energy-intensive user, characterized by outdated plants, has been considered and an alternative solution has been evaluated. The results obtained are: an operating cost reduction of 97,510 €/year, a cost of energy reduction (from 0.170 €/kWh to 0.130 €/kWh), and a reduction of CO<sub>2</sub> emission of 139 Mg/year. Furthermore, three different energy storage systems have been considered: Pb-Ac batteries, flywheels and micro-CAES. The results show that storage systems and CHP are effective in co-operation, during the hours of peak load demand. The model proposed in this study is a flexible system and it has a positive impact on the main grid; moreover, the presence of storage systems produces an increase on the flexibility, through interactions with the components of the multi-energy system. A systematic application of these kind of systems can produce a significant reduction of electricity absorbed from the main grid, producing in turn several benefits, such as a reduction of CO<sub>2</sub> emissions and a time-shift of the peak of electric power requested from the grid, which produces a decongestion of the main grid in the central hours of the day.

## Author Contributions

All the authors are involved in preparing the manuscript.

## Conflicts of Interest

The authors declare no conflict of interest.

## Nomenclature

Symbol	Description	Unit Measure
$V$	Volume	$m^3$
$S$	Surface	$m^2$
$COE$	Cost Of Energy	€/kWh
$PES$	Primary Energy Saving	%J
$\eta$	Efficiency	
<i>Heating/Cooling</i>	Heating/Cooling Demand	kWh/year

## References

- Bhattacharyya, S.C. Energy access programs and sustainable development: A critical review and analysis. *Energy Sustain. Dev.* **2012**, *16*, 260–271.
- European Parliament. *Directive 2009/28/EC of the European Parliament and of the Council of 23 April 2009 on the Promotion of the Use of Energy from Renewable Sources and Amending and Subsequently Repealing Directives 2001/77/EC and 2003/30/EC*; Official Journal of the European Union: Strasbourg, France, 2009.
- European Parliament. *Directive 2004/8/EC of the European Parliament and of the Council of 11 February 2004 on the Promotion of Cogeneration Based on a Useful Heat Demand in the Internal Energy Market*; Official Journal of the European Union: Strasbourg, France, 2004.
- Manwell, J.F. Hybrid energy system. *Encycl. Energy* **2004**, *3*, 215–229.
- Allegrini, J.; Orehounig, K.; Mavromatidis, G.; Ruesch, F.; Dorer, V.; Evins, R. A review of modeling approaches and tools for the simulation of district-scale-energy systems. *Renew. Sustain. Energy Rev.* **2015**, *52*, 1391–1404.
- Mancarella, P. MES (Multi-energy systems): An overview of concepts and evaluation models. *Energy* **2014**, *65*, 1–7.
- Sharif, A.; Almansoori, A.; Fowler, M.; Elkamel, A.; Alrafea, K. Design of an energy hub based on natural gas and renewable energy sources. *Int. J. Energy Res.* **2013**, *38*, 363–373.
- Fabrizio, E.; Filippi, M. *La Valutazione del Sistema Multi Energia a Servizio Dell'edificio: Procedura di Simulazione Dinamica Attraverso la Metodologia Dell'energia Hub*; Dario Flaccovio Editore: Palermo, Italy, 2008.
- Brenna, M.; Falvo, M.C.; Foiadelli, F.; Martirano, L.; Massaro, F.; Vaccaro, A. Challenges in Energy system for the smart-cities of the future. In Proceedings of the 2nd IEEE ENERGYCON Conference & Exhibition, 2012/Future Energy Grids and Systems Symposium, Florence, Italy, 9–12 September 2012.
- Ascomac Cogena: i vantaggi dei sistemi SDC/RIU/SEU abbinati a reti intelligenti. Available online: [http://www.casaclima.com/index.php?option=com\\_content&view=article&id=16038:ascomac-cogena-i-vantaggi-dei-sistemi-sdcruiseu-abbinati-a-reti-intelligenti&catid=1:latest-news&Itemid=50](http://www.casaclima.com/index.php?option=com_content&view=article&id=16038:ascomac-cogena-i-vantaggi-dei-sistemi-sdcruiseu-abbinati-a-reti-intelligenti&catid=1:latest-news&Itemid=50) (accessed on 13 October 2014). (In Italian)
- Geidl, M.; Andersson, G. Operational and structural optimization of multi-carrier energy systems. *Eur. Trans. Electr. Power* **2006**, *16*, 463–477.

12. Geidl, M.; Andersson, G. Optimal power flow of multiple energy carriers. *IEEE Trans. Power Syst.* **2007**, *2*, 145–155.
13. Parisio, A.; del Vecchio, C.; Vaccaro, A. A robust optimization approach to energy hub management. *Int. J. Electr. Power Energy Syst.* **2012**, *42*, 98–104.
14. Nazar, M.S.; Haghifam, M.R. Multiobjective electric distribution system expansion planning using hybrid energy hub concept. *Electr. Power Syst. Res.* **2009**, *79*, 899–911.
15. Pazouki, S.; Haghifam, M.-R.; Moser, A. Uncertainty modeling in optimal operation of energy hub in presence of wind, storage and demand response. *Int. J. Electr. Power Energy Syst.* **2014**, *61*, 335–345.
16. La Scala, M.; Vaccaro, A.; Zobaa, A. A goal programming methodology for multiobjective optimization of distributed energy hubs operation. *Appl. Therm. Eng.* **2013**, *71*, 658–666.
17. Givler, T.; Lilienthal, P. Using HOMER® Software, NREL's Micro Power Optimization Model, to Explore the Role of Gen-Sets in Small Solar Power Systems Case Study: Sri Lanka. Available online: <http://www.nrel.gov/docs/fy05osti/36774.pdf> (accessed on 13 October 2015).
18. Hafez, O.; Bhattacharya, K. Optimal planning and design of a renewable energy based supply system for microgrids. *Renew. Energy* **2012**, *45*, 7–15.
19. Himri, Y.; Stambouli, A.B.; Draoui, B.; Himri, S. Techno-economical study of hybrid power system for a remote village in Algeria. *Energy* **2008**, *33*, 1128–1136.
20. Nandi, S.; Ghosh, H.R. Prospect of wind-PV-Battery hybrid system as an alternative to grid extension in Bangladesh. *Energy* **2010**, *35*, 3040–3047.
21. Nfah, E.M.; Ngundam, J.M.; Vandenberg, M.; Schmid, J. Simulation of off-grid generation options for remote villages in Cameroon. *Renew. Energy* **2008**, *33*, 1064–1072.
22. Bekele, G.; Palm, B. Feasibility study for a sustainable solar-wind based hybrid Energy system for application in Ethiopia. *Appl. Energy* **2010**, *87*, 487–495.
23. TRNSYS. Available online: [www.trnsys.com](http://www.trnsys.com) (accessed on 13 October 2015).
24. HOMER. Available online: [www.homerenergy.com](http://www.homerenergy.com) (accessed on 13 October 2015).
25. Bottillo, S.; Vollaro, A.D.L.; Galli, G.; Vallati, A. Fluid dynamic and heat transfer parameters in an urban canyon. *Sol. Energy* **2014**, *99*, 1–10.
26. Bottillo, S.; Vollaro, A.D.L.; Galli, G.; Vallati, A. CFD modeling of the impact of solar radiation in a tridimensional urban canyon at different wind conditions. *Sol. Energy* **2014**, *102*, 212–222.
27. Galli, G.; Vallati, A.; Recchiuti, C.; de Lieto Vollaro, R.; Botta, F. Passive cooling design options to improve thermal comfort in an Urban District of Rome, under hot summer conditions. *Int. J. Eng. Technol.* **2013**, *5*, 4495–4500.
28. De Lieto Vollaro, A.; de Simone, G.; Romagnoli, R.; Vallati, A.; Botillo, S. Numerical study of urban canyon microclimate related to geometrical parameters. *Sustainability* **2014**, *6*, 7894–7905.
29. De Lieto Vollaro, R.; Vallati, A.; Bottillo, S. Different Methods to Estimate the Mean Radiant Temperature in an Urban Canyon. *Adv. Mater. Res.* **2013**, *650*, 647–651.
30. Lund, H.; Mathiesen, B.V. Energy System Analyses of 100% renewable energy system—The case of Denmark in year 2030 and 2050. *Energy* **2009**, *34*, 524–531.
31. Inage, S.-I. *Prospect for a Large Scale Energy Storage in Decarbonized Power Grids*; International Energy Agency: Paris, France, 2009.



32. Alessandrini, F.; Appetecchi, G.B.; Conte, M. *Studio di Fattibilità Tecnica Sull'applicabilità Delle Batterie al Litio Nelle Reti Elettriche—Stato Dell'arte e Limiti Scientifici e Tecnologici*; Report; ENEA (Italian National Agency for New Technologies, Energy and Sustainable Economic Development): Rome, Italy, 2010. Available online: [http://www.enea.it/it/Ricerca\\_sviluppo/documenti/ricerca-di-sistema-elettrico/elettrotecnologie/16-rt-enea-ob-f-29-9-10.pdf](http://www.enea.it/it/Ricerca_sviluppo/documenti/ricerca-di-sistema-elettrico/elettrotecnologie/16-rt-enea-ob-f-29-9-10.pdf) (accessed on 13 October 2015). (In Italian)
33. Liu, W.; Yang, Y.; Zhang, W.; Xu, G.; Wu, Y. A Novel Hybrid-Fuel Compressed Air Energy Storage System for China's Situation. *Energies* **2014**, *7*, 4988–5010.
34. Ferreira, H.L.; Garde, R.; Fulli, G.; Kling, W.; Lopes, J.P. Characterization of electrical energy storage technologies. *Energy* **2012**, *53*, 288–298.

© 2015 by the authors; licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution license (<http://creativecommons.org/licenses/by/4.0/>).

RETRACTED